



ORIGINAL PERMIT APPLICANT(S)

JANNA FLANDERS
 RICHARD FLANDERS

APPROVED WELL LOCATION

Water Division: 2 Water District: 10
 Designated Basin: N/A
 Management District: N/A
 County: EL PASO
 Parcel Name: N/A
 Physical Address: N/A

NE 1/4 NE 1/4 Section 23 Township 12.0 S Range 66.0 W Sixth P.M.

UTM COORDINATES (Meters, Zone:13, NAD83)

Easting: 522376.0 Northing: 4316456.0

PERMIT TO CONSTRUCT A NEW WELL

**ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT
CONDITIONS OF APPROVAL**

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-90-137(4) on the condition that this well is operated in accordance with the augmentation plan approved by the Division 2 Water Court in Case No. 16CW3041 and Division 1 Water Court Case No. 16CW3095. If the well is not operated in accordance with the terms of said decree, it will be subject to administration including orders to cease diverting water. This well is known as Augmented Well.
- 4) The use of ground water from this well is limited to indoor use inside one guest house (0.27 acre-foot/year), the irrigation of a small garden and the watering of horses or equivalent livestock (0.13 acre-foot/year).
- 5) The pumping rate of this well shall not exceed 15 GPM.
- 6) The annual amount of ground water to be withdrawn shall not exceed 0.40 acre-foot.
- 7) Production is limited to the Denver aquifer which is located 300 feet below land surface and extends to a depth of 1195 feet. Plain casing must be installed and grouted to prevent the withdrawal of ground water from other aquifers and the movement of ground water between aquifers.
- 8) The return flow from the use of this well must be through an individual waste water disposal system of the non-evaporative type where the water is returned to the same stream system in which the well is located.
- 9) The entire length of the hole shall be geophysically logged as required by Rule 9 of the Statewide Nontributary Ground Water Rules prior to installing casing.
- 10) The owner shall mark the well in a conspicuous location with well permit number(s), name of the aquifer, and court case number(s) as appropriate. The owner shall take necessary means and precautions to preserve these markings.
- 11) A totalizing flow meter must be installed on this well and maintained in good working order. Permanent records of all diversions must be maintained by the well owner (recorded at least annually) and submitted to the Division Engineer upon request.
- 12) This well shall be constructed not more than 200 feet from the location specified on this permit.

NOTE: To ensure a maximum productive life of this well, perforated casing should be set through the entire producing interval of the approved zone or aquifer indicated above.

NOTE: This well will be completed in a Type I aquifer penetrating only one confining layer and must be constructed in accordance with Well Construction Rule 10.4.5.1 (2 CCR 402-2).

WELL PERMIT NUMBER 81459-F

RECEIPT NUMBER 3682807

NOTE: This permit will expire on the expiration date unless the well is constructed and a pump is installed by that date. A Well Construction and Yield Estimate Report (GWS-31) and Pump Installation and Production Equipment Test Report (GWS-32) must be submitted to the Division of Water Resources to verify the well has been constructed and the pump has been installed. A one-time extension of the expiration date may be available. Contact the DWR for additional information or refer to the extension request form (GWS-64) available at: <http://www.water.state.co.us>

NOTICE: This permit has been approved subject to the following changes: The UTM coordinate values, quarter/quarter, quarter, Section, Township, Range and P.M. were determined from the survey map and distances from section lines provided with the permit application. You are hereby notified that you have the right to appeal the issuance of this permit, by filing a written request with this office within sixty (60) days of the date of issuance, pursuant to the State Administrative Procedures Act. (See Section 24-4-104 through 106, C.R.S.)



Issued By AILIS THYNE

Date Issued: 10/25/2017

Expiration Date: 10/25/2018