



Prevent • Promote • Protect

Environmental Health Division  
1675 W. Garden of the Gods Road  
Suite 2044  
Colorado Springs, CO 80907  
(719) 578-3199 *phone*  
(719) 578-3188 *fax*  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)

**Wylie Addition, Administrative Relief, ADR-17-013**

**Please accept the following comments from El Paso County Public Health regarding the project referenced above:**

- **Although the proposed addition is on the north side of the house, please note that the on-site wastewater treatment system (OWTS) records indicate the OWTS is located on the south side of the house. Advise contractors not to drive or park in this area should your request be approved. Compaction of the soil treatment area may lead to premature system failure.**

**Mike McCarthy, R.E.H.S.  
El Paso County Public Health  
Environmental Health Division  
719.575.8602  
[mikemccarthy@elpasoco.com](mailto:mikemccarthy@elpasoco.com)  
10Oct2017**