



Prevent • Promote • Protect

Environmental Health Division  
1675 W. Garden of the Gods Road  
Suite 2044  
Colorado Springs, CO 80907  
(719) 578-3199 *phone*  
(719) 578-3188 *fax*  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)

### **Colorado Parks and Wildlife Ranch Shooting Range, U-19-001**

Please accept the following comments from El Paso County Public Health for the project referenced above:

- Earthmoving activity in excess of one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information. Earthmoving activities greater than 25 acres require a Construction Activity Permit from the Colorado Department of Public Health and Environment, Air Pollution Control Division. Go to: <https://www.colorado.gov/pacific/cdphe/general-air-permits>
- No water or wastewater service plans were included with the submittal review materials.
- If a water system is planned for the shooting range, then it must comply with the requirements of the Colorado Department of Public Health and Environment (CDPHE), Water Quality Control Division (WQCD).
- If an onsite wastewater treatment system (OWTS) is planned for the shooting range, then it must be sized and designed by a Colorado Registered Professional Engineer. NOTE: Portable toilets are for temporary use only.

Mike McCarthy, R.E.H.S.  
El Paso County Public Health  
Environmental Health Division  
719.575.8602  
[mikemccarthy@elpasoco.com](mailto:mikemccarthy@elpasoco.com)  
29Jan2019