



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Falcon High School Expansion, PPR-17-048

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- The proposed expansion to Falcon High School will be provided water and wastewater services through Meridian Ranch Metropolitan District.
- Radon resistant construction building techniques/practices are encouraged to be used in this area. The EPA has determined that Colorado, and the El Paso County area have potentially higher radon levels than other areas of the country.
- A Construction Activity Permit (PT0040105) from El Paso County Public Health has been issued for the site earthwork.
- El Paso County Public Health encourages, but does not require, the interior finish plans to be submitted for comment prior to commencement of construction.

Mike McCarthy, R.E.H.S
El Paso County Public Health
Environmental Health Division
719.575.8602
mikemccarthy@elpasoco.com
13Nov2017