

ENG-PUDSP20005-R6-CD-Util-redlines.pdf Markup Summary


1 (1)




Subject: Callout
Page Index: 1
Date: 7/19/2021 8:36:08 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] U0.0

Signatures are needed

9 (4)




Subject:
Page Index: 9
Date: 7/19/2021 8:51:32 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] U1.2



Subject: Length Measurement
Page Index: 9
Date: 7/21/2021 3:37:02 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] U1.2

32'-0"



Subject: Length Measurement
Page Index: 9
Date: 7/21/2021 3:37:36 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] U1.2

10'-1 1/2"



Subject: Callout
Page Index: 9
Date: 7/21/2021 3:42:12 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] U1.2

Inlet is 30' per PDR, will not fit with utilities as shown.

11 (1)



Subject: Callout
Page Index: 11
Date: 7/19/2021 8:55:57 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] U2.4

Is this going to be bored under BGMD?