Form No. GWS-25

OFFICE OF THE STATE ENGINEER
COLORADO DIVISION OF WATER RESOURCES

818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

LIC

WELL PERMIT NUMBER 206657 - - A

DIV. 2 CNTY. 21 WD 10 DES. BASIN MD

Lot: Block: Filing: Subdiv:

APPLICANT

DOROTHIE INGRAM
% DOUG BARBER
5160 N UNION BLVD
COLO SPRINGS CO 80918-

(719)598-3198

APPROVED WELL LOCATION
EL PASO COUNTY
NE 1/4 NE 1/4 Section 18
Twp 12 S RANGE 65 W 6th P.M.

DISTANCES FROM SECTION LINES
151 Ft. from North Section Line
270 Ft. from East Section Line

PERMIT TO CONSTRUCT A WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of the permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.

2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.

3) Approved pursuant to CRS 37-92-602(3)(c) for the relocation of an existing well, permit no. 206657 The old well must be plugged and sealed according to the Water Well Construction and Pump Installation Rules within ninety (90) days of completion of the new well. **The enclosed Well Abandonment Report form must be completed and submitted to affirm that the old well was properly plugged and sealed.**

4) The use of this well is limited to drinking and sanitary facilities only in an individual commercial business as described in CRS 37-92-602(1)(c). This business is described as 7 small businesses located within a strip mall. Water from this well shall not be used for any uses outside the business building structure, including lawn or landscape irrigation, or animal watering.

5) Approved as the only well providing water to this business, which is on a 11.04 acre parcel, described as that portion of the NE1/4 of the NE1/4 of Section 18, Twp. 12 South, Rng. 65 East, 6th P.M., being more particularly described by the attached exhibit A.

6) The maximum pumping rate shall not exceed 15 GPM.

7) The **maximum annual amount** of ground water to be withdrawn **shall not exceed 1 acre-foot (325,900 gallons).**

8) Plain casing must be installed and properly sealed to a minimum depth of 115 feet to prevent diversion of water above this depth. The depth of the well shall not exceed 680 feet, which corresponds to the base of the Dawson aquifer.

9) A totalizing flow meter must be installed on this well and maintained in good working order. Permanent records of all diversions must be maintained by the well owner, and recorded on a monthly, and yearly basis. **Copies of these records are to be provided to the Water District 10 Water Commissioner following the end of each water year (concluding September 30th – To be forwarded no later than December 1st of the same calendar year).**

10) Emergency verbal approval **nos. 97VE416 & 97VE422**, were given on September 30, 1997 and October 2, 1997 respectively, for construction of this well.

APPROVED
HCF

Hal D. Simpson
State Engineer

By

Receipt No. 0421795B DATE ISSUED NOV 24 1997 EXPIRATION DATE NOV 24 1999