

OFFICE OF THE STATE ENGINEER
COLORADO DIVISION OF WATER RESOURCES
818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

LIC

WELL PERMIT NUMBER 62746 -F -
DIV. 2 WD 10 DES. BASIN MD

APPLICANT

Lot: 1 Block: Filing: Subdiv: TAY LOR

CAL PHILIP & KATHLEEN MARIE MARTIN
6910 JUNIPER DR
COLORADO SPRINGS, CO 80908-

(719) 495-0523

APPROVED WELL LOCATION

EL PASO COUNTY
SW 1/4 NW 1/4 Section 17
Township 12 S Range 65 W Sixth P.M.

DISTANCES FROM SECTION LINES

2440 Ft. from North Section Line
600 Ft. from West Section Line

UTM COORDINATES (Meters, Zone: 13, NAD83)

Easting: Northing:

CHANGE/EXPANSION OF USE OF AN EXISTING WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

Page 1 of 2

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
3) Approved pursuant to CRS 37-90-137(4) on the condition that this well is operated in accordance with the Cal Phillip and Kathleen Marie Martin augmentation plan approved by the Division 2 Water Court in Case No. 04CW3 and the Division 1 Water Court in Case No. 04CW19. If the well is not operated in accordance with the terms of said decree, it will be subject to administration including orders to cease diverting water.
4) Approved for the expansion of use for an existing well constructed under permit number 151741. The issuance of this permit hereby cancels permit number 151741.
5) The use of ground water from this well is limited to fire protection, ordinary household purposes inside one (1) single family dwellings, use in hot tubs and swimming pools, the irrigation of not more than 0.25 acres of home gardens and lawns, the watering of poultry, domestic animals, and livestock, and augmentation.
6) The pumping rate of this well shall not exceed 15 GPM.
7) The total depth of the well shall not exceed 620 feet, which corresponds to the base of the Dawson aquifer. At a minimum, plain casing shall be installed and grouted through all unconsolidated materials and shall extend a minimum of ten feet into the bedrock formation to prevent production from other zones.
8) The average annual amount of ground water to be appropriated shall not exceed 0.9 acre-feet (293,300 gallons).
9) The return flow from the use of this well must be through an individual waste water disposal system of the non-evaporative type where the water is returned to the same stream system in which the well is located.
10) The owner shall mark the well in a conspicuous place with well permit number(s), name of the aquifer, and court case number(s) as appropriate. The owner shall take necessary means and precautions to preserve these markings.
11) A totalizing flow meter must be installed on this well and maintained in good working order. Permanent records of all diversions must be maintained by the well owner (recorded at least annually) and submitted to the Division Engineer upon request.
12) This well shall be constructed at least 600 feet from any existing well, completed in the same aquifer, that is not owned by the applicant.
13) This well shall be not more than 200 feet from the location specified on this permit.

APPROVED
CDK

State Engineer (Signature)

By (Signature)

Receipt No. 0539552

DATE ISSUED 06-08-2005

EXPIRATION DATE 06-08-2006

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT
CONDITIONS OF APPROVAL

14) This well is subject to administration by the Division Engineer in accordance with applicable decrees, statutes, rules, and regulations.

NOTE: To ensure a maximum productive life of this well, perforated casing should be set through the entire producing interval of the approved zone or aquifer indicated above.

NOTE: The ability of this well to withdraw its authorized amount of water from this non-renewable aquifer may be less than the 100 years upon which the amount of water in the aquifer is allocated, due to anticipated water level declines. *CDK 6/8/05*