



Prevent • Promote • Protect

Environmental Health Division  
1675 W. Garden of the Gods Road  
Suite 2044  
Colorado Springs, CO 80907  
(719) 578-3199 *phone*  
(719) 578-3188 *fax*  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)

April 26, 2017

**BooDad's Beach House Grill COM-17-012**

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- The application did not provide information regarding water and wastewater services for the proposed concession stand/outdoor bar. Please provide additional information.
- Radon resistant construction building techniques/practices are encouraged to be used in this area. The EPA has determined that Colorado, and the El Paso County area, have potentially higher radon levels than other areas of the country.
- Earthmoving activity in excess of one acre, but less than twenty-five acres, will require a Construction Activity Permit from El Paso County Public Health. Go to <http://www.elpasocountyhealth.org/service/air-quality> for more information.

Aaron Doussett, M.S., R.E.H.S.  
Program Manager, Environmental Health Division  
El Paso County Public Health  
1675 W. Garden of the Gods Rd.  
Colorado Springs, Colorado 80907  
Office: (719) 578-3131  
Cell: (719) 235-1740  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)