



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

McConnel Rezone, P-18-007

Please accept the following comments from El Paso County Public Health (EPCPH) regarding the 40.00 acre, development project referenced above:

- **There are no public health issues with the proposed rezone noted by El Paso County Public Health.**
- **There is an existing 2002 permitted and approved Onsite Wastewater Treatment System (OWTS) installed at 11150 North Ellicott Highway. The soil test performed on the property was satisfactory for the installation of a conventional (non-engineer designed) OWTS. Per the Letter of Intent there are other soil tests available on the site that support OWTS installations. Copies were not submitted for review, nor are they required for approval.**
- **A finding for sufficiency in terms of water quality is assumed for minor subdivisions, and water quality sampling and testing is not necessary.**

**Mike McCarthy, R.E.H.S.
El Paso County Public Health
mikemccarthy@elpasoco.com
719-575-8602
29Nov2018**