



Prevent • Promote • Protect

Environmental Health Division  
1675 W. Garden of the Gods Road  
Suite 2044  
Colorado Springs, CO 80907  
(719) 578-3199 *phone*  
(719) 578-3188 *fax*  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)

**Christian Construction Inc. RHOC, AL-19-030**

**Please accept the following comments from El Paso County Public Health regarding the proposed equipment storage:**

- **A record of a 1999 approved and permitted on-site wastewater treatment system (OWTS) for the existing house indicates the OWTS components are located slightly north and east of the house. Please make sure the existing OWTS septic tank, soil treatment area (STA) and an equally sized STA replacement area remain protected from vehicular damage by compaction. The septic tank is an approved plastic tank but is not traffic rated. The STA is not designed to be driven over and compaction will result in early system failure.**
- **Please locate the existing OWTS components and protect them in some manner from being compacted.**
- **No other public health issues noted with the proposal.**

**Mike McCarthy**  
El Paso County Public Health  
Environmental Health Division  
[mikemccarthy@elpasoco.com](mailto:mikemccarthy@elpasoco.com)  
719.575.8602  
30Jan2020