

**OFFICE OF THE STATE ENGINEER
COLORADO DIVISION OF WATER RESOURCES**
818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

797

APPLICANT

7/10
To: Gordon
From: Bill

BILL BRADLEY
61 WESTCLIFFE DR
SAM ISABEL, CO 81069-8650

WELL PERMIT NUMBER 269502
DIV. 2 WD 10 DES. BASIN MD

Lot: 6 Block: Filing: Subdiv: TURKEY CANYON RANCH ESTATES

APPROVED WELL LOCATION

EL PASO COUNTY
SW 1/4 SW 1/4 Section 28
Township 16 S Range 67 W Sixth P.M.

DISTANCES FROM SECTION LINES

1216 Ft. from South Section Line
139 Ft. from West Section Line

UTM COORDINATES (Meters, Zone: 13, NAD83)

Easting: Northing:

(719) 485-6161

PERMIT TO CONSTRUCT A WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-92-602(3)(b)(II)(A) as the only well on a tract of land of 38.73 acres described as lot 6, Turkey Canyon Ranch Estates division of land, El Paso County.
- 4) The use of ground water from this well is limited to fire protection, ordinary household purposes inside not more than three (3) single family dwellings, the watering of poultry, domestic animals and livestock on a farm or ranch and the irrigation of not more than one (1) acre of home gardens and lawns.
- 5) The pumping rate of this well shall not exceed 15 GPM.
- 6) The return flow from the use of this well must be through an individual waste water disposal system of the non-evaporative type where the water is returned to the same stream system in which the well is located.
- 7) This well shall be constructed not more than 200 feet from the location specified on this permit.

NOTICE: This permit has been approved subject to the following changes: the acreage was obtained from the plat map submitted with the application. The uses were changed to be consistent with the uses allowed for a parcel larger than 35 acres. You are hereby notified that you have the right to appeal the issuance of this permit, by filing a written request with this office within sixty (60) days of the date of issuance, pursuant to the State Administrative Procedures Act. (See Section 24-4-104 through 106, C.R.S.) *CDK 6/22/06*

APPROVED
CDK

Hal D. Simpson
State Engineer

Receipt No. 3604893

DATE ISSUED 06-22-2006

By *Chy Kim*

EXPIRATION DATE 06-22-2008