
Environmental Health Review Comments

AL268: Rural Home Occ. SU Equipment Storage

Please accept the following comments from El Paso County Public Health (EPCPH) regarding the project referenced above:

- El Paso County Public Health (EPCPH) has no concerns with the requested addition of a storage building to the property as there are no public health impacts associated.
- Radon resistant construction techniques/practices are encouraged to be used in this area. The EPA has determined that Colorado, and the El Paso County area have potentially higher radon levels than other areas of the country.
- Earthmoving activity in excess of one acre, but less than twenty-five acres, will require a Construction Activity Permit from El Paso County Public Health. Visit <https://www.elpasocountyhealth.org/licenses-permits-inspections-water-testing/air-quality/> for additional information.

For any additional questions or comments, please contact us at HEAEH_Landuse@elpasoco.com. While every effort is made for timely responses, allow 2 to 3 business days for a response from our field staff.