



Hanover Fire Protection District
13325 Old Pueblo Road
Fountain, CO 80817
(719)382-1900



To Dave Iadarola
Project Manager for Front Range-Midway Solar Project
From Chief Tatum
Hanover Fire Protection District

Re: Commitment Letter

Dear Dave:

Based upon our discussions over the past year or so, and the information we have exchanged, we are providing this commitment letter to provide Fire and EMS service for this project. This commitment letter to provide service is on condition of the final project proposal submission to El Paso County Land Development services.

Hanover Fire Department still reserves the right to review and provide feedback on the submitted project packet. We will be interested in how this project will address the road impacts, the primary roads for the construction to be brought up to all season access and what roads may be close or restrict access to the area during the construction phase of the project. We will be also interested in the Pioneer Community access to their homes during this process and how they will ensure access is not limited during the construction.

Hanover fire at this time does not believe there will be an adverse impact to our ability to provide service to this project from the previous talks we have had with the project manager. We will request that there is Knox boxes at all main gates to each solar farm for fire department access. During the project construction we would like to have some class room training for firefighter and EMS workers on hazards we may come across and sight training once the construction is completed. We are also looking for weed control plans on the outside and inside of the fence area. We are also looking for all season access interior roads next to the fences for vehicle access.

If you have any question please give me a call.

Carl Tatum
Hanover Fire Chief
13325 Old Pueblo Rd
Fountain Colorado 80817
Office 719-382-1900
Cell 719-492-2729
hanover3500@aol.com