



ORIGINAL PERMIT APPLICANT(S)

KEVIN COLVIN
 MICHELLE COLVIN

Well permit needs to be updated, this indicates the well only serves 1 single family dwelling.

APPROVED WELL LOCATION

Water Division: 2 Water District: 10
 Designated Basin: UPPER BLACK SQUIRREL CREEK
 Management District: UPPER BLACK SQUIRREL
 County: EL PASO
 Parcel Name: N/A
 Physical Address: N/A
 SE 1/4 SE 1/4 Section 15 Township 12.0 S Range 65.0 W Sixth P.M.

UTM COORDINATES (Meters, Zone:13, NAD83)

Easting: 530731.0 Northing: 4316838.0

PERMIT TO CONSTRUCT A NEW WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT
CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-90-107(7) and the Findings and Order of the Colorado Ground Water Commission dated March 4, 2019, for Determination of Water Right No. 3655-BD and its associated Replacement Plan.
- 4) The use of ground water from this well is limited to domestic use inside 1 single family dwelling, including the watering of 4 domestic animals and the irrigation of 13,000 square feet of lawns and gardens. The place of use shall be limited to the 19.8 acre land area claimed in the above described Order of the Commission.
- 5) The pumping rate of this well shall not exceed 15 GPM.
- 6) The annual withdrawal of ground water from this well shall not exceed 1 acre-foot, subject to the total annual withdrawal limitations and conditions as specified by the above referenced Order of the Commission.
- 7) This well must be constructed to withdraw water only from the Dawson aquifer. The total depth of the well shall not exceed 785 feet, which corresponds to the base of the aquifer. At a minimum, plain casing shall be installed and grouted through all unconsolidated materials and shall extend a minimum of ten feet into the bedrock formation to prevent production from other zones.
- 8) The owner shall mark the well in a conspicuous location with the well permit number and name of aquifer as appropriate, and shall take necessary means and precautions to preserve these markings.
- 9) This well shall be constructed within 200 feet of the location specified on this permit. This well shall not be located within 600 feet of another large-capacity well completed in the Dawson aquifer.
- 10) The entire length of the hole shall be geophysically logged as required by Rule 9 of the Statewide Nontributary Ground Water Rules prior to installing casing.
- 11) A totalizing flow meter or Commission approved measuring device must be installed on this well and maintained in good working order. Permanent records of all diversions must be maintained by the well owner (collected at least annually) and submitted to the Upper Black Squirrel Creek Ground Water Management District and the Ground Water Commission upon request.
- 12) The return flows from the in house supply component of this well use have been claimed as a replacement source, pursuant to the Findings and Order of the Commission dated March 4, 2019. As a result, the return flow from the use of this well must be through an individual waste water disposal system of the non-evaporative type where the water is returned to the same stream system in which the well is located.

NOTE: This well is located within the Upper Black Squirrel Creek Ground Water Management District where local District Rules apply which may further limit the withdrawal and use of designated ground water as authorized under this permit. The District requires permanent records of all diversions be maintained and submitted to the District monthly.

WELL PERMIT NUMBER 83066-F

RECEIPT NUMBER 3690831

NOTE: The ability of this well to withdraw its authorized amount of water from this non-renewable aquifer may be less than the 100 years upon which the amount of water in the aquifer is allocated, due to anticipated water level declines.

NOTE: This permit has been approved with a change to the permit application as submitted by the applicant. The irrigated acres have been reduced to coincide with Determination of Water Right 3655-BD and an annual appropriation of 1 acre-foot per year. You are hereby notified that you have the right to appeal the issuance of this permit, by filing a written request with this office within sixty (60) days of the date of issuance, pursuant to the State Administrative Procedures Act. (See Section 24-4-104 through 106, C.R.S.)

NOTE: This permit will expire on the expiration date unless the well is constructed by that date. A Well Construction and Yield Estimate Report (GWS-31) must be submitted to the Division of Water Resources to verify the well has been constructed. A one-time extension of the expiration date may be available. Contact the DWR for additional information or refer to the extension request form (GWS-64) available at: <http://www.water.state.co.us>



Date Issued: 4/3/2019

Expiration Date: 4/3/2020

Issued By SHANNON PORTER