



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

6035 Sioux Trail, BOA-18-007

Please accept the following comments from El Paso County Public Health for the project referenced above:

- Water service for the existing home is by central water.
- Wastewater service for the project is provided by an onsite wastewater treatment system (OWTS) installed in 1998 for a 3-bedroom house. The 1998 OWTS replaced the original cesspool from 1948.
- The existing soil treatment area of the 1998 OWTS and a secondary site for an alternate soil treatment area, should the original site fail, must be located and protected from possible compaction by vehicle traffic or parking. Fencing of these areas is recommended, but not required.
- No other public health issues noted with the setback proposals.

Mike McCarthy, R.E.H.S.
Environmental Health Division
El Paso County Public Health
719.575.8602
mikemccarthy@elpasoco.com
13Nov2018