

**WA** Presumptive Use Values. In the absence of data on water use to the contrary or other minimum values established as acceptable by the State Engineer, the following presumptive values will be used to calculate the annual water demand:

- Residential inside use 0.26 acre feet per year for single family residences and 0.20 acre feet per year for each occupancy unit in multiple family residences other than single family. A duplex contains 2 occupancy units, a triplex contains 3 occupancy units, etc.;
- Residential and commercial landscaping use 0.0566 acre feet per 1,000 square feet of landscaping;
- Commercial and industrial inside use 0.1 gallon per day for each square foot of developed space; and
- Miscellaneous irrigation (landscaping, golf courses, etc.) use 2.46 acre feet per acre per year.

Section 30-28-133(d), C.R.S. req  
is sufficient in terms of quan

1. NAME OF DEVELOPMENT AS PROPOSED <b>Wyoming Estates</b>	
2. LAND USE ACTION <b>Minor Subdiv</b>	
3. NAME OF EXISTING PARCEL AS RECORDED	
SUBDIVISION	FILING
4. TOTAL ACREAGE <b>40</b>	5. NUMB
6. PARCEL HISTORY - Please attach copies of de	
A. Was parcel recorded with county prior to June B. Has the parcel ever been part of a division of if yes, describe the previous action	
7. LOCATION OF PARCEL - Include a map deliniating the project area and tie to a section corner.	
SE 1/4 OF NW 1/4 SECTION 33 TOWNSHIP 13 N (X) RANGE 64 E (X) W PRINCIPAL MERIDIAN: <input checked="" type="checkbox"/> 6TH <input type="checkbox"/> N.M.	
8. PLAT - Location of all wells on property must be plotted and permit numbers provided. Surveyors plat <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If not, scaled hand drawn sketch <input type="checkbox"/> Yes <input type="checkbox"/> No	
9. ESTIMATED WATER REQUIREMENTS - Gallons per Day or Acre Feet per Year	10. WATER SUPPLY SOURCE
HOUSEHOLD USE # <b>4</b> of units _____ GPD <b>1.0</b> AF COMMERCIAL USE # _____ of S.F. _____ GPD _____ AF IRRIGATION # _____ ft _____ Up to .082 AF STOCK WATERING # _____ if head _____ up to 0.82 AF OTHER _____ GPD _____ AF TOTAL <b>please complete this section and indicate the no. of livestock.</b> GF <b>1.82</b> AF/Yr	<input type="checkbox"/> EXISTING WELLS <input type="checkbox"/> DEVELOPED SPRING <input type="checkbox"/> NEW WELLS - PROPOSED AQUIFERS - (CHECK ONE) <input type="checkbox"/> ALLUVIAL <input checked="" type="checkbox"/> 1 <sup>ST</sup> ARAPAHOE <input type="checkbox"/> UPPER GANSON <input type="checkbox"/> 2 <sup>ND</sup> ARAPAHOE <input type="checkbox"/> LOWER GANSON <input type="checkbox"/> LARAMIE FOX HILLS <input type="checkbox"/> DENVER <input type="checkbox"/> DAKOTA <input type="checkbox"/> OTHER _____  <input type="checkbox"/> MUNICIPAL <input type="checkbox"/> ASSOCIATION <input type="checkbox"/> COMPANY <input type="checkbox"/> DISTRICT NAME _____ LETTER OF COMMITMENT FOR SERVICE <input type="checkbox"/> YES <input type="checkbox"/> NO  Determination Of Water Rights WATER COURT DECREE CASE NO.'S <b>3542-BD</b> <b>3542-BD-RP</b>
11. ENGINEER'S WATER SUPPLY REPORT <input type="checkbox"/> YES <input type="checkbox"/> NO IF YES, PLEASE FORWARD WITH THIS FORM. (This may be required before our review is completed.)	
12. TYPE OF SEWAGE DISPOSAL SYSTEM	
<input checked="" type="checkbox"/> SEPTIC TANK/LEACH FIELD <input type="checkbox"/> LAGOON <input type="checkbox"/> ENGINEERED SYSTEM (Attach a copy of engineering design)	<input type="checkbox"/> CENTRAL SYSTEM - DISTRICT NAME _____ <input type="checkbox"/> VAULT - LOCATION SEWAGE HAULED TO <b>this was not provided</b> <input type="checkbox"/> OTHER _____

The presumptive value for a residence is .26 and you are estimating .25 per residence. Please either revise or provide justification for why the subdivision will utilize less water.