



Prevent • Promote • Protect

Environmental Health Division  
1675 W. Garden of the Gods Road  
Suite 2044  
Colorado Springs, CO 80907  
(719) 578-3199 *phone*  
(719) 578-3188 *fax*  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)

### **Peyton Fire Protection District Unmanned Station, EX-23-4**

Please accept the following comments from El Paso County Public Health for the project referenced above:

- Earthmoving activity more than one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information.
- No water or wastewater services were mentioned with the submittal; however, if a restroom is planned, even though the station will be unmanned, the onsite wastewater treatment system must be permitted and approved by El Paso County Public Health.
- An individual well is likely planned for the site. The water system is unregulated by El Paso County Public Health.

Mike McCarthy  
El Paso County Public Health  
719-332-5771  
[mikemccarthy@elpasoco.com](mailto:mikemccarthy@elpasoco.com)  
26January2024