

# Stormwater Detention and Infiltration Design Data Sheet

*SDI-Design Data v2.00, Released January 2020*

Stormwater Facility Name: **Citizen On Constitution-Extended Detention Facility**

Facility Location & Jurisdiction: **SWC of Constitution Avenue and Marksheffel Road- El Paso County, CO**

### User Input: Watershed Characteristics

Extended Detention Basin (EDB) ▼	EDB	
Watershed Area =	11.25	acres
Watershed Length =	1,200	ft
Watershed Length to Centroid =	600	ft
Watershed Slope =	0.020	ft/ft
Watershed Imperviousness =	71.0%	percent
Percentage Hydrologic Soil Group A =	66.5%	percent
Percentage Hydrologic Soil Group B =	33.5%	percent
Percentage Hydrologic Soil Groups C/D =	0.0%	percent
Target WQCV Drain Time =	40.0	hours

Location for 1-hr Rainfall Depths (use dropdown):

▼

After providing required inputs above including 1-hour rainfall depths, click 'Run CUHP' to generate runoff hydrographs using the embedded Colorado Urban Hydrograph Procedure.

Once CUHP has been run and the Stage-Area-Discharge information has been provided, click 'Process Data' to interpolate the Stage-Area-Volume-Discharge data and generate summary results in the table below. Once this is complete, click 'Print to PDF'.

User Defined Stage [ft]	User Defined Area [ft^2]	User Defined Stage [ft]	User Defined Discharge [cfs]
0.00	10	0.00	0.00
1.23	1,075	1.23	0.05
2.23	5,842	2.23	0.07
3.23	8,472	3.23	0.13
4.23	10,582	4.23	0.18
5.23	12,841	5.23	0.32
6.23	15,225	6.23	0.51
7.23	17,729	7.23	0.61
8.23	20,348	8.23	0.70
9.23	23,172	9.23	0.78
10.03	25,384	10.03	0.84

After completing and printing this worksheet to a pdf, go to:  
<https://maperture.digitaldataservices.com/gvh/?viewer=cswdif>  
 Create a new stormwater facility, and attach the PDF of this worksheet to that record.

### Routed Hydrograph Results

Design Storm Return Period =	WQCV	2 Year	5 Year	10 Year	50 Year	100 Year	
One-Hour Rainfall Depth =	N/A	1.19	1.52	1.75	2.25	2.55	in
CUHP Runoff Volume =	0.262	0.746	0.986	1.177	1.663	1.974	acre-ft
Inflow Hydrograph Volume =	N/A	0.746	0.986	1.177	1.663	1.974	acre-ft
Time to Drain 97% of Inflow Volume =	38.0	65.2	<b>71.2</b>	74.5	81.3	84.8	hours
Time to Drain 99% of Inflow Volume =	40.3	69.1	75.8	79.8	88.3	<b>92.9</b>	hours
Maximum Ponding Depth =	3.25	5.09	5.81	6.33	7.53	8.20	ft
Maximum Ponded Area =	0.20	0.29	0.33	0.36	0.42	<b>0.47</b>	acres
Maximum Volume Stored =	0.263	0.703	0.926	1.104	1.567	1.868	acre-ft

# Stormwater Detention and Infiltration Design Data Sheet

