



**ENTECH**  
 ENGINEERING, INC.  
 505 Elkton Drive  
 Colorado Springs, CO 80907  
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	Cola, LLC
Project:	Trails at Aspen Ridge
Entech Job #	191072

**CONCRETE TEST**

<b>LM</b>			<b>Test #: 126</b>		
Date:	# of Specimens	Specified Strength (psi)	Time of Test	Hours Field Cured	Lab Receive Date:
11/24/2021	4	4500	12:10 PM	48	11/26/2021
<b>Specimen Type</b>		<b>Test Type</b>		<b>Type of Cure</b>	
<b>Cylinders 4x8</b>		<b>Field</b>		<b>Tank</b>	
Contractor:		Supplier:		Mix Design Number	
<b>Concrete Concepts</b>		<b>Transit Mix</b>		<b>T34592110</b>	
Truck Number		Ticket Number		Batch Time:	
<b>31</b>		<b>86486721</b>		<b>11:22 AM</b>	

Location:  
 Curb & Gutter; Northeast corner of the intersection of Moose Meadow Street & Legacy Hill Drive.

Slump (in.):	Air (%):	Unit Weight (PCF):	Concrete Temp (°F)	Air Temp (°F)
3.5	6.5	137.8	67	45

7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength
3790				
Average:	Average:	Average:	Average:	Average:
3790				
Break Date:	Break Date:	Break Date:	Break Date:	Break Date:
12/1/2021	12/22/2021			

Remarks:  
 7 Day Results

Specifications: 4500 PSI, 5-8% Air, 4" Max Slump	Break Sequence: 1@7, 3@28
---	------------------------------

Summary Comments:  
 Concrete Concepts, Transit Mix

Reviewed By: