



June 15, 2021

Ryan Howser
El Paso County Development Services
2880 International Circle, Suite 110
Colorado Springs, CO 80910

SUBJECT: Engineering Review Comment
Mountain View Electric Association Inc. (The Association)

To El Paso County:

The Association has these comments about the following:

Project Name: Woodmoor WSD - Lake Pump Station and Transmission Pipeline

Project Number: PPR2119

Description: Proposed development to build a new pump station and transmission main at Lake Woodmoor Dr. in Township 11, Range 67, Sections 11 and 14.

Please reference the comment letter dated April 22, 2021. The Association requests a ten (10) foot clearance from any wet utilities being installed.

This area is within the Association's certificated service area. The Association will serve this area according to our Line Extension policy. Connection requirements may include provisions for necessary line extensions and or other system improvements, and payment of all fees under the Association's Line Extension Policy. Information concerning these requirements can be obtained by contacting the Engineering Department.

The Association has existing facilities near and within this parcel of land. If there is any damage, removal or relocation of facilities it will be at the expense of the applicant.

If additional information is required, please contact me at (719) 494-2636. Our office hours are 7:00 a.m. to 5:30 p.m., Monday – Thursday.

Sincerely,

Gina Perry
Engineering Coordinator II

This Association is an equal opportunity provider and employer.

