



ENTECH
ENGINEERING, INC.

505 ELKTON DRIVE
COLORADO SPRINGS, CO 80907
PHONE (719) 531-5599
FAX (719) 531-5238

August 19, 2022

COLA, LLC
555 Middle Creek Parkway, Suite 500
Colorado Springs, CO 80921

Attn: Mark Hollenbeck

Re: Density Testing – Sanitary Sewer
10407 Kalama
Colorado Springs, Colorado
Report No. 1, Test 1

Dear Ms. Hollenbeck,

As requested, personnel of Entech Engineering, Inc. have performed density testing at the above referenced site.

Density testing on this site was performed on July 20, 2022. The density testing indicates that the materials have been adequately compacted at the depths and in the locations noted. Results of the density tests are enclosed with this letter.

We trust that this has provided you with the information you require. Should you have any questions or need further information, please do not hesitate to contact us.

Respectfully Submitted,

ENTECH ENGINEERING, INC.


Joseph C. Goode, Jr., P.E.
President

JCG/lu

Enclosure

Entech Job No. 221623

F:\AA projects\2022\221623-COLA-10407 Kalama-100-DE\221623_2cl1.docx



Client: COLA, LLC	Entech Job #: 221623.2	Proctor Value Key: M = modified, ASTM D-1557
Project: 10407 Kalama	Tested By: C. Harris	S = standard, ASTM D-698
Subject: Sanitary Sewer	Report Date: 08-19-2022	T = AASHTO, T-180


Test #	Location	Testing Date	Percent Compaction	Percent Required	Percent Moisture	Soil Type	Proctor Type/Value	Pass/Fail
--------	----------	--------------	--------------------	------------------	------------------	-----------	--------------------	-----------

1	5' north and 18' west off the northwest corner of driveway at 10407 Kalama St, at grade.	7/20/2022	95	95	13.5	SM	M - 118.5 @ 11.7	<input checked="" type="checkbox"/>
---	--	-----------	----	----	------	----	------------------	-------------------------------------

Comments:

The density testing indicates that the materials have been adequately compacted at the depths and in the locations noted.
 Scope of Observation: PERIODIC; CONTRACTOR'S OR CLIENT'S REPRESENTATIVE ADVISED

All dimensions are approximate. Cl. = Centerline

 <p>ENTECH ENGINEERING, INC. 505 Elkton Drive Colorado Springs, CO 80907 (719) 531-5599 • (719) 531-5238 (fax)</p>	<p>FIELD DENSITY RESULTS</p>	<p><i>Joseph C. Goode, Jr., P.E.</i></p>
--	------------------------------	--