



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

March 28, 2017

Bradley Storage – PPR-17-011

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- The proposed site development will be provided water and wastewater services by Security Water District.
- Radon resistant construction building techniques/practices are encouraged to be used in this area. The EPA has determined that Colorado, and the El Paso County area, have potentially higher radon levels than other areas of the country.
- Earthmoving activity in excess of one acre, but less than twenty-five acres, will require a Construction Activity Permit from El Paso County Public Health. Go to <http://www.elpasocountyhealth.org/service/air-quality> for more information.

Aaron Doussett, M.S., R.E.H.S.
Program Manager, Environmental Health Division
El Paso County Public Health
1675 W. Garden of the Gods Rd.
Colorado Springs, Colorado 80907
Office: (719) 578-3131
Cell: (719) 235-1740
www.elpasocountyhealth.org