



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Windermere, SP-19-3

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- There is a finding for sufficiency in terms of water quality for drinking water obtained from this Colorado Department of Public Health and Environment, Water Quality Control Division, regulated central water supply. The water system is assigned the PWSID# CO-0121325 from the Colorado Department of Public Health and Environment for Garden Valley Water and Sanitation.
 - Cherokee Metropolitan District (CMD) has provided a Letter of Commitment dated 15Jun2020 for water and wastewater services.
 - The Drexel, Barrell & Co. Water Resources Report for Windermere dated 04Feb2019, was also reviewed for approval.
 - The Drexel, Barrell, and Co. Wastewater Report for Windermere dated Sept2020, was reviewed to support wastewater service approval.
- Earthmoving activities greater than 25 acres require a Construction Activity Permit from the Colorado Department of Public Health and Environment, Air Pollution Control Division. Go to: <https://www.colorado.gov/pacific/cdphe/general-air-permits>
- Water quality basins must have mosquito control responsibilities included as a part of the construction design and maintenance plan to help control mosquito breeding habitat and minimize the potential for West Nile Virus.
- Radon resistant construction building techniques/practices are encouraged in this area. The EPA has determined that Colorado, and specifically the El Paso County area, have higher radon levels than other areas of the country.

Mike McCarthy
El Paso County Public Health
719.575.8602
mikemccarthy@elpasoco.com
09Jan2021