



**Preliminary Acceptance Punchlist**  
**El Paso County – Department of Public Works - Stormwater Section**

Project Name:	Rolling Hills Ranch Filing 3
EDARP Filing Number(s):	SF2116
ESQCP Number:	ESQ2329
Attendees:	DPW SW: Dylan Finley DPW Development Services: Brad Walters, David Parkerson, Spencer Pirzadeh, Gilbert LaForce Developer: Lawrence Grahem
Date of Walk-Thru:	08/02/2023
Walk-Thru Number:	1

*Please have all items completed within six months of the date on this punchlist. If all items are not completed within six months, a new punchlist will be created. When all items are completed, please let your inspector know as soon as possible so they can come out to the project to confirm.*

Findings to be addressed prior to scheduling a follow-up walk-thru:

**Culverts [Construction Drawings Sheet 15]:**

- Storm #1, install outlet protection per plans. Riprap overburdened with sediment. (Photo 5)

**Stormwater Inlet Structures:** All inlets requiring maintenance marked in the field with green paint.

- Inlets need to be cleaned of sediment:
  - Inlet #21: Rolling Ranch Dr. and Crooked Hill Dr. (Photo 1)
  - Inlet #20: Coastal Hills and Crooked Hill Dr. (Photo 2)
  - Inlet #19: Crooked Bluff Dr. and Crooked Hill (Photo 3)
  - Inlet #22: Along Rolling Ranch Dr. (Photo 4)

**Photos:**



Photo 1: Inlet at Rolling Ranch Dr. and Crooked Hill Dr.



Photo 2: Inlet at Coastal Hills and Crooked Hill Dr.




Photo 3: Inlet at Crooked Bluff Dr. and Crooked Hill



Photo 4: Inlet at Along Rolling Ranch Dr.



Photo 5: Storm #1, install outlet protection per plans. Riprap overburdened with sediment. Remove sediment and reestablish outlet protection.