


EPC DPW Stormwater-SWMP Comments.pdf Markup Summary


8 (2)



Subject: SW - Highlight
Page Label: 8
Author: Mikayla Hartford
Date: 7/29/2026 5:24:05 PM
Status:
Color: 
Layer:
Space:

5.95 acres. The estimated area of the site to be disturbed by all construction-related activities is approximately 5.12 acres.

DMC RESPONSE: Areas revised. Parcel area is 6.03 acres, total site area is 6.18 acres, total disturbed area is 6.18 acres




Subject: SW - Textbox
Page Label: 8
Author: Mikayla Hartford
Date: 7/29/2026 5:24:25 PM
Status:
Color: 
Layer:
Space:

Doesn't match the ESQCP. Verify and ensure both match.

DMC RESPONSE: ESQCP to be revised to match updated quantities.


22 (2)



Subject: SW - Highlight
Page Label: 22
Author: Mikayla Hartford
Date: 7/30/2026 10:16:28 AM
Status:
Color: 
Layer:
Space:

areas at least three feet from curb flow lines and paved/driving surfaces, storm drains, or retention areas

DMC RESPONSE: Updated to include additional language on portable toilet requirements.



Subject: SW - Textbox with Arrow
Page Label: 22
Author: Mikayla Hartford
Date: 7/30/2026 10:20:55 AM
Status:
Color: 
Layer:
Space:

Portable toilets will be located a minimum of 10ft from stormwater inlets and 50ft from state waters. They will be secured at all four corners to prevent overturning and cleaned on a weekly basis. They will be inspected daily for spills.

DMC RESPONSE: Updated to include additional language on portable toilet requirements.