

EPC DPW Stormwater-GEC Checklist Comments.pdf Markup Summary

1 (1)

I CONTROL I

: PPR2619

Subject: SW - Textbox
Page Label: 1
Author: Mikayla Hartford
Date: 7/30/2026 10:23:27 AM
Status:
Color: ■
Layer:
Space:

PPR2619

DMC RESPONSE: Number added


2 (4)



Subject: SW - Highlight
Page Label: 2
Author: Mikayla Hartford
Date: 7/30/2026 10:44:52 AM
Status:
Color: ■
Layer:
Space:

Temporary sediment ponds provided for disturbed drainage areas greater than 1 acre

DMC RESPONSE: Response changed from N/A to X



Subject: Text Box
Page Label: 2
Author: Mikayla Hartford
Date: 7/30/2026 10:45:01 AM
Status:
Color: ■
Layer:
Space:

Y

DMC RESPONSE: Response changed from N/A to X



Subject: SW - Highlight
Page Label: 2
Author: Mikayla Hartford
Date: 7/30/2026 10:56:07 AM
Status:
Color: ■
Layer:
Space:

Details for all proposed temporary construction control measures to include information on dimensions, installation, materials, and maintenance requirements. Custom or other jurisdiction's details used must meet or exceed EPC standards

DMC RESPONSE: Additional details have been included in plans to account for existing BMPs as well as BMPs included in latest plans



Subject: Text Box
Page Label: 2
Author: Mikayla Hartford
Date: 7/30/2026 10:56:14 AM
Status:
Color: ■
Layer:
Space:

N

DMC RESPONSE: Additional details have been included in plans to account for existing BMPs as well as BMPs included in latest plans