

EPC DPW Stormwater-PCM O&M Manual Comments.pdf Markup Summary

2 (1)		
is Substation () TBD). PPR26196 Public Health	Subject: SW - Textbox	PPR26196
	Page Label: 2	
	Author: Mikayla Hartford	
	Date: 7/30/2026 10:24:53 AM	
	Status:	
	Color: ■	DMC RESPONSE: Number added
	Layer:	
	Space:	

3 (1)		
floatables from blocking the outlet orifices. TING EXTENDED DETENTION BASINS (EDBs) cess and Easements nd maintenance personnel may utilize the attached s location(s) of the access points and maintenance eas ment. See comments on GEC Plan and adjust as needed. stormwater management practices locations id maintenance personnel may utilize the attached stor the location(s) of the EDB(s) within this development. Extended Detention Basin (EDB) Features number of features that are designed to serve a particu as of one feature dominates an outlet. For example	Subject: SW - Textbox	See comments on GEC Plan and adjust O&M as needed.
	Page Label: 3	
	Author: Mikayla Hartford	
	Date: 7/30/2026 10:26:07 AM	
	Status:	
	Color: ■	DMC RESPONSE: Additional language has been added referencing the 10' access road and confirming accessibility and traversability by owners maintenance staff.
	Layer:	
	Space:	