



ENG-CDR20004-R4-MDDP.pdf Markup Summary


#00FFFF (6)



Subject: Highlight
Page Index: 12
Date: 5/6/2022 12:47:45 PM
Author: dsdrice
Color: 
Layer:
Space:
Page Label: 12

, but for continuity the Amendment SWMM model has flows from basin SC3-15A routing through Pond FSD15B.

e culvert. It
is 1580 cfs
ldv nools is

Subject: Highlight
Page Index: 17
Date: 5/6/2022 1:29:09 PM
Author: dsdrice
Color: 
Layer:
Space:
Page Label: 17


1580

he amended
is 1827 cfs
one through

Subject: Highlight
Page Index: 18
Date: 5/6/2022 1:28:35 PM
Author: dsdrice
Color: 
Layer:
Space:
Page Label: 18

1827

hydrology, t
is 1,627 cfs
slope through

Subject: Highlight
Page Index: 18
Date: 5/6/2022 1:29:18 PM
Author: dsdrice
Color: 
Layer:
Space:
Page Label: 18

1,627

Subject: Highlight
Page Index: 108
Date: 5/6/2022 11:21:00 AM
Author: dsdrice
Color: 
Layer:
Space:
Page Label: 108

135.5 325% 6.2 520% 68.04 467%



Subject: Highlight
Page Index: 346
Date: 5/6/2022 11:55:17 AM
Author: dsdrice
Color: 
Layer:
Space:
Page Label: 346




Subject: Callout
Page Index: 7
Date: 5/6/2022 11:37:36 AM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 7

and includes an additional XX acres of contributing area proposed to be diverted to the main Sand Creek channel



Subject: Callout
Page Index: 12
Date: 5/6/2022 12:48:47 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 12


This should address how the flows are handled with the current approved plans and construction.



Pond W-3, the amount of stor

Subject: Callout
Page Index: 16
Date: 5/6/2022 12:55:08 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 16

verify values



Subject: Callout
Page Index: 16
Date: 5/6/2022 1:23:37 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 16

Staff has forwarded to the City for concurrence. What would the difference be without the diversion? A footnote about what Classic is planning should be added.

ensively to grade in the
1,643?
ned MDDP hydrology,
erling Ranch, is 1,627 c


Subject: Callout
Page Index: 18
Date: 5/6/2022 1:27:56 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 18

1,643?




Subject: Callout
Page Index: 18
Date: 5/6/2022 1:32:23 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 18

Address bank stabilization along the west side of the channel in the Homestead North development (from the Wheatland Drive cul-de-sac to Poco Road) and along Filing 3 at the south end.




Subject: Callout
Page Index: 81
Date: 5/6/2022 2:39:04 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 81

Does SC-15A go straight to DP-87?




Subject: Callout
Page Index: 105
Date: 5/6/2022 2:40:32 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 105

This should address how the flows are handled with the current approved plans and construction. The previous comment was that detention is assumed west of Vollmer, which could be modeled or just mentioned, with the model conveying flows through the approved bypass pipe.




Subject: Callout
Page Index: 108
Date: 5/6/2022 2:32:45 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 108

verify values



Subject: Callout
Page Index: 346
Date: 5/6/2022 11:56:38 AM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 346

Need existing and proposed?



Subject: Callout
Page Index: 346
Date: 5/10/2022 11:32:09 AM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 346