



Prevent • Promote • Protect

Environmental Health Division  
1675 W. Garden of the Gods Road  
Suite 2044  
Colorado Springs, CO 80907  
(719) 578-3199 *phone*  
(719) 578-3188 *fax*  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)

**City of Colorado Springs-Tutt Road and Cottonwood Drainage Project,**  
**EX-19-001**

Please accept the following comment from El Paso County Public Health for the project referenced above:

- The 23April2019 letter submitted by Bugenhagen Septic Specialists showed the existing onsite wastewater treatment system (OWTS) meets the minimum installation setbacks required in Chapter 8 of the El Paso County Board of Health Regulations for Onsite Wastewater Treatment Systems after the 1.74-acre piece is obtained by the City of Colorado Springs.
- Please be aware that area sufficient for the repair or replacement of the existing soil treatment area must be preserved on the remaining 3.28-acre lot.
- No other issues noted by El Paso County Public Health with the approval of this exemption request.

Mike McCarthy  
El Paso County Public Health  
Environmental Health Division  
719.575.8602  
[mikemccarthy@elpasoco.com](mailto:mikemccarthy@elpasoco.com)  
01Jun2019