



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

City of Colorado Springs-Tutt Road and Cottonwood Drainage Project,
EX-19-001

Please accept the following comments from El Paso County Public Health for the project referenced above:

- The existing onsite wastewater treatment system (OWTS) must be entirely located on the remaining 3+ acres and meet all minimum horizontal installation setbacks found in the El Paso County Board of Health, Chapter 8, Onsite Wastewater Treatment System Regulations. This includes the location of the well.
- No other public health issues noted with the smaller lot if the above condition is satisfied.

Mike McCarthy, R.E.H.S.
Environmental Health Division
El Paso County Public Health
719.575.8602
mikemccarthy@elpasoco.com
01Mar2019