


ENG-EGP22006-R1-GEC.pdf Markup Summary

1 (3)



Subject: Stormwater Comments Color
Page Index: 1
Date: 3/14/2023 4:42:40 PM
Author: dotprete
Color: ■
Layer:
Space:
Page Label: [1] 1 2514207CV02 - CV01



Subject: Callout
Page Index: 226
Date: 3/21/2023 12:58:05 PM
Author: Jeff Rice - EPC Engineering Review
Color: ■
Layer:
Space:
Page Label: [1] 1 2514207CV02 - CV01

3

4.1
-

Subject:
Page Index: 1
Date: 3/21/2023 12:58:29 PM
Author: Jeff Rice - EPC Engineering Review
Color: ■
Layer:
Space:
Page Label: [1] 1 2514207CV02 - CV01


4 (1)



Subject: Text Box
Page Index: 4
Date: 3/14/2023 4:50:12 PM
Author: dotprete
Color: ■
Layer:
Space:
Page Label: [6] 5 F5 GEC1


Label adjacent city/town/jurisdictional boundaries, subdivision names, and property parcel numbers

6 (10)




Subject: Cloud+
Page Index: 6
Date: 3/13/2023 5:32:44 PM
Author: dotprete
Color: ■
Layer:
Space:
Page Label: [9] 8 DT03

since this is an EGP, remove this bullet and keep BMPs in place for subsequent construction




Subject: Text Box
Page Index: 6
Date: 3/14/2023 4:18:20 PM
Author: dotprete
Color: ■
Layer:
Space:
Page Label: [9] 8 DT03

show the TSB spillway location




Subject: Text Box
Page Index: 6
Date: 3/14/2023 4:18:45 PM
Author: dotprete
Color: ■
Layer:
Space:
Page Label: [9] 8 DT03

show the TSB spillway location



Subject: PolyLine
Page Index: 6
Date: 3/14/2023 4:59:13 PM
Author: dotprete
Color: ■
Layer:
Space:
Page Label: [9] 8 DT03




Subject: Callout
Page Index: 6
Date: 3/14/2023 4:59:23 PM
Author: dotprete
Color: ■
Layer:
Space:
Page Label: [9] 8 DT03

add silt fence




Subject: Callout
Page Index: 6
Date: 3/14/2023 5:00:19 PM
Author: dotprete
Color: ■
Layer:
Space:
Page Label: [9] 8 DT03

Need owner permission to grade offsite. Provide copy of owner permission to EPC.



Subject: Text Box
Page Index: 6
Date: 3/14/2023 5:02:57 PM
Author: dotprete
Color: ■
Layer:
Space:
Page Label: [9] 8 DT03

show on plans




Subject: Callout
Page Index: 6
Date: 3/15/2023 9:12:11 AM
Author: Jeff Rice - EPC Engineering Review
Color: ■
Layer:
Space:
Page Label: [9] 8 DT03

Is an offsite easement required?



Subject: Callout
Page Index: 6
Date: 3/15/2023 9:14:59 AM
Author: Jeff Rice - EPC Engineering Review
Color: ■
Layer:
Space:
Page Label: [9] 8 DT03


Spillway should be on this side to minimize impacts to downstream property



Subject: Callout
Page Index: 6
Date: 3/21/2023 1:01:00 PM
Author: Jeff Rice - EPC Engineering Review
Color: ■
Layer:
Space:
Page Label: [9] 8 DT03

Call out grading in the SFHA and discuss permitting with the Regional Floodplain Administrator

8 (1)



Subject: Text Box
Page Index: 8
Date: 3/13/2023 5:35:55 PM
Author: dotprete
Color: ■
Layer:
Space:
Page Label: [9] 8 DT03

Replace with EPC approved VTC detail (VT-1 and VT-2 in DCMv2, Chap 3.3) or revise to be 75ft min length.