



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Eagles Nest Wellness Center Greenhouses, PPR-17-049

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- Water service for the two proposed greenhouses is by an existing individual well.
- Wastewater service for the project is provided by an existing onsite wastewater treatment system (OWTS) that was installed in 1967 for an existing house. The Site Development Plan submitted shows an approximate location of the existing septic tank that does not correspond with the permitted OWTS component locations. Therefore, prior to any construction or any onsite grading, all components (septic tank, building sewer lines, and the soil treatment area) must be located. Measures must be taken to protect all the OWTS components from damage by construction vehicles and construction activities.
- An OWTS Minor Repair Permit is required, if necessary, for the relocation of any portion of the building sewer lines.

Mike McCarthy, R.E.H.S.
El Paso County Public Health
Environmental Health Division
719.575.8602
mikemccarthy@elpasoco.com
09Mar2018