



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

CPC DP 18-00151, MVS Development LLC

- Earthmoving activity in excess of one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information.
- The storm water quality detention basin must have mosquito control responsibilities included as a part of the maintenance plan to help control mosquito breeding habitat and minimize the potential for West Nile Virus. The lined storm water detention pond plans include the possibility of capturing the storm flow and allowing the water to evaporate. In this case, the stagnant water is to be treated with an approved larvicide during mosquito breeding season.
- The applicant must comply with all Colorado Department of Public Health and Environment review comments for all required waste removal from the site, and the terms of the required issuance of a Certificate of Designation for the long term landfill waste consolidation area located on the property.

Mike McCarthy, R.E.H.S.
Environmental Health Division
El Paso County Public Health
719.575.8602
mikemccarthy@elpasoco.com
25Jan2019