



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	Classic Communities
Project:	Forest Lakes, Filing 2
Entech Job #:	152313

CONCRETE TEST

MS			Test #:	1	
Date:	# of Specimens:	Specified Strength (psi):	Time of Test:	Hours Field Cured:	Lab Receive Date:
11/10/2016	4	4500	1:00 PM	24	11/11/2016

Specimen Type	Test Type	Type of Cure
Cylinders 4x8	Field	Tank

Contractor:	Supplier:	Mix Design Number:
Classic	Transit Mix	14582110
Truck Number:	Ticket Number:	Batch Time:
086	271554	12:00 pm

Location:
 Outlet Drop Structure, Tract A

Slump (in.):	Air (%):	Unit Weight (PCF):	Concrete Temp (°F):	Air Temp (°F):
2.5	5.5		70	68

7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength
4780				
Average:	Average:	Average:	Average:	Average:
4780				
Break Date:	Break Date:	Break Date:	Break Date:	Break Date:
11/17/2016	12/5/2016			

Remarks:
 7 day results

Specifications:	Break Sequence:
4"Max Slump, 4.5-7.5%Air	1@7, 2@28, 1-Hold

Summary Comments:
 Transit

Reviewed By: *mtt*