

Kevin Mastin, Interim Executive Director  
El Paso County Planning & Community Development  
O: 719-520-6300  
KevinMastin@elpasoco.com  
2880 International Circle, Suite 110  
Colorado Springs, CO 80910

Board of County Commissioners  
Holly Williams, District 1  
Carrie Geitner, District 2  
Stan VanderWerf, District 3  
Longinos Gonzalez, Jr., District 4  
Cami Bremer, District 5

August 22, 2022

County File: OAR2285

Re: Whataburger Prelim PUD

To: Debbie Flynn; dflynn@tomgov.org

### Planning Division

Note that El Paso County does not have land use authority over property within the City of Colorado Springs; however, it is recommended that the development follow these regulations for this site to ensure that proper measures are taken to ensure compatibility between the proposed use within the City and the existing neighborhood and surrounding properties in the County.

El Paso County LDC §6.2.2(D)(2) requires a Buffer Between Non-Residential and Residential Districts Separated by a Non-Arterial Road or Public Alley.

- (1) **Where Required.** A buffer is required along the road-side lot, parcel, or tract line of any non-residential use where the use is separated from a residential zoning district by a non-arterial road or public alley.
- (2) **Depth and Planting Standards.** The required buffer shall be a minimum of 15 feet deep. The minimum number of trees in the buffer shall be 1 tree for every 15 feet of the road frontage. A minimum of  $\frac{1}{3}$  of the trees shall be evergreen trees.
- (3) **Opaque Fence or Wall Required.** An opaque fence or wall with a minimum height of 6 feet is required along the inside edge of the required buffer when the area immediately adjacent to the 15 foot buffer is used as a service corridor for loading, maneuvering or storage. If the area is used for parking, the required parking lot screening shall be applicable.
- (4) **Minimum Ground Covering Required.** The required buffer area shall require a ground cover at maturity with a minimum of 75% living plant materials. Bark, wood chips, rock, stone, or other natural landscape material shall be used as a non-living ground cover. Areas of a required buffer not covered in approved living ground cover material shall be covered in an approved non-living ground cover.

Reviewed by: Ashlyn Mathy, Planner I  
Ashlynmathy2@gmail.com

### Engineering Division

No comments. Access via public road within Town of Monument (TOM) jurisdiction. Drainage is provided by a regional pond within TOM jurisdiction and not expected to negatively impact unincorporated EPC properties in the vicinity of the site.

Reviewed by:

Gilbert LaForce, PE  
gilbertlaforce@elpasoco.com

**County Engineer (Public Works)**

Additional comments may be provided by the County Engineer.

Ashlyn Mathy, Planner I  
El Paso County Development Services  
2880 International Circle, Colorado Springs, CO, 80910  
(719) 520-6447

