



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Woodmen Hills, Filing No. 12, SF-20-22

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- **Water service will be provided by Woodmen Hills Metropolitan District (WHMD). The water system is assigned the PWSID #CO0121930 from the Colorado Department of Public Health and Environment. There is a finding of sufficiency in terms of water quality for the project. The JDS-Hydro Consultants, Inc., Water Resources Report dated December 2020, supports the adequacy of water for the project. There is a Letter of Commitment to provide water from Woodmen Hills Metropolitan District on file for the project.**
- **Wastewater service to be provided by Woodmen Hills Metropolitan District. The JDS-Hydro Consultants, Inc., Wastewater Disposal Report dated December 2020, supports the adequacy of wastewater treatment and capacity for the project. There is a Letter of Commitment to provide wastewater service from Woodmen Hills Metropolitan District on file for the project.**
- **Radon resistant construction building techniques/practices are encouraged to be used in this area. The EPA has determined that Colorado, and the El Paso County area have potentially higher radon levels than other areas of the country.**

Mike McCarthy
El Paso County Public Health
719.575-8602
mikemccarthy@elpasoco.com
01Apr2021