



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Monument Tank Site and 5.6 Miles of Water Lines, PPR-21-30

Please accept the following comments from El Paso County Public Health for the project referenced above:

- The proposed storage tank and water lines must be constructed to meet the minimum requirements of the Colorado Department of Public Health and Environment, Water Quality Control Division, Design Criteria Manual for Water Storage Tanks and water lines.
- Earthmoving activity more than one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information.

Mike McCarthy
El Paso County Public Health
719-332-5771
mikemccarthy@elpasoco.com
25Feb2022