

Sunset Village Filing 4 Phase 1

Preliminary Acceptance – Stormwater

Benjamin Jones, Glenn Reese

08/01/2022

- Storm drain inlet manhole covers missing
- Clean all three storm drains of debris/sediment
- Install all pond components per details