




PHOTOMETRIC
UPDATED PER
REVISION 1

Schedule									
Symbol	Label	Image	QTY	Catalog Number	Description	Lamp	Number Lamps	Lumens per Lamp	LLF Wattage
	A		5	DSX1 LED P1 40K 70CRI TSM HS	D-Series Size 1 Area Luminaire P1 Performance Package 4000K CCT 70 CRI Type 2 Medium Housework Shield		1	5763	1 50.9015
	B		1	DSX1 LED P1 40K 70CRI TSM HS	D-Series Size 1 Area Luminaire P1 Performance Package 4000K CCT 70 CRI Type 2 Medium Housework Shield		1	5763	1 101.803
	D		2	DSX2 LED P1 40K 70CRI AFR HS	D-Series Size 0 Area Luminaire P1 Performance Package 4000K CCT 70 CRI Automotive Front Row Housework Shield		1	4697	1 33.21

Statistics						
Description	Symbol	Avg	Max	Min	Max/Min	Avg/Min
Catch Zone #2	+	1.1 fc	4.7 fc	0.0 fc	N/A	N/A

D-Series Size 1 LED Area Luminaire

Specifications

Size: 18" x 18" x 12"

Length: 18"

Width: 18"

Height: 12"

Weight: 25 lbs

Ordering Information

EXAMPLE: DSX1 LED P1 40K 70CRI TSM HS NLTARD PRSHV DSDSD

Symbol	Label	Description	Quantity	Unit	Notes
DSX1	DSX1 LED P1 40K 70CRI TSM HS	D-Series Size 1 Area Luminaire P1 Performance Package 4000K CCT 70 CRI Type 2 Medium Housework Shield	5	EA	
DSX2	DSX2 LED P1 40K 70CRI AFR HS	D-Series Size 0 Area Luminaire P1 Performance Package 4000K CCT 70 CRI Automotive Front Row Housework Shield	2	EA	

Ordering Information

Accessories


External Glass Shield (EGS)

House Side Shield (HSS)

Baseplate Mounting Signifier

Technical Data

Parameter	Value
Light Output (lm)	5763
Beam Spread (deg)	120
Mounting Height (ft)	10-12




TYPICAL LIGHT POLE FOUNDATION DETAIL

NEWGROUND

ARCHITECT

ARNO SANDOVAL, AIA, NCARB

15451 South Outer Forty Drive, Suite 300
Cheverly, MD 20717
696.886.8100
Certificate No. - C-3064



07/08/2026

DO NOT REPRODUCE
This document contains confidential information, and is an instrument of service and property of the architect. It shall not be used on other projects or for the extension of this project without the Architect's written approval.

SHELL BUILDING OWL PLACE CO

7885 MERIDIAN PARK DRIVE
PEYTON, CO 80831

Revisions:		
#	Description	Date
1	PHOTOMETRIC U	07/08/2026

Issue Date:

Designer:

Drawn By:

Check By: A. HERNANDEZ

Project No: Q-511220002

Package: 90% CD SET

Title:

PHOTOMETRIC

Sheet No.

PH100.00