



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

18884 and 19004 Hilltop Pines, SF-19-016

Please accept the following comments from El Paso County Public Health for the project referenced above:

- There are no known public health issues identified with the lot line adjustment.
- Be aware future onsite wastewater treatment systems (OWTS) soil treatment areas on both lots must be a minimum of 100' from this well and any other surrounding well. Placement of a future well and OWTS on Lot 1 requires more critical planning.

Mike McCarthy
El Paso County Public Health
Environmental Health Division
719.575.8602
mikemccarthy@elpasoco.com
21Nov2019