



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Cathedral Rock Church, PPR-24-36

Please accept the following comments from El Paso County Public Health for the development request referenced above:

- Donala Water and Sanitation District is designated as providing water and wastewater services to the development. There is a finding of sufficiency in terms of quality for water from this Colorado Department of Public Health and Environment regulated community water system. PWSID #CO0121175
- Earthmoving activity more than one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information.
- The water quality basin is encouraged have mosquito control responsibilities included as a part of the construction design and maintenance plan to help control mosquito breeding habitat and minimize the potential for West Nile Virus.
- Interior finish plans for all El Paso County Public Health regulated facilities (if any, maybe the child care) must be submitted to El Paso County Public Health for review and approval prior to commencement of the project. Contact El Paso County Public Health at 719-578-3199, option 3.

Mike McCarthy
El Paso County Public Health
719-332-5771
mikemccarthy@elpasoco.com
15November2024