

ENG-PUDSP20007-R4-PDRFDR.pdf Markup Summary

1 (1)

CLASS

Subject: Text Box

See comment letter also

Page Index: 1

See comment letter also

Date: 2/16/2022 1:06:55 PM

Author: dsdrice

Color: ■

Layer:

Space:

Page Label: 1

9 (2)



Subject: Cloud+

The pond needs to be based on HSG A which calculates the required release rates based on existing soil types

Page Index: 9

Date: 2/16/2022 12:13:18 PM

Author: dsdrice

Color: ■

Layer:

Space:

Page Label: 9



Subject: Callout

upon acceptance of the public improvements

Page Index: 9

Date: 2/16/2022 12:15:12 PM

Author: dsdrice

Color: ■

Layer:

Space:

Page Label: 9

53 (1)



Subject: Callout

this needs to be existing condition soils

Page Index: 53

Date: 2/16/2022 12:28:33 PM

Author: dsdrice


Color: ■

Layer:

Space:

Page Label: 53

67 (3)



Subject: Callout

Add a label describing the channel improvements and a cross-section of the channel

Page Index: 67

Date: 2/16/2022 12:33:04 PM


Author: dsdrice

Color: ■

Layer:

Space:

Page Label: 67



Subject: Callout
Page Index: 67
Date: 2/16/2022 1:58:43 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 67

Provide dimensions and cross-sections of the spillway. Final design details and calculations are needed since this is a final drainage report.



Subject: Callout
Page Index: 67
Date: 2/16/2022 12:40:32 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: 67

What happened to the gas line previously shown here?