



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Grandview Reserve Lift Station Forcemain Interceptor at Saddlehorn,
PPR-24-21

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- **The proposed new lift station must meet the permitting requirements and the design criteria for lift stations of the Colorado Department of Public Health and Environment (CDPHE), Water Quality Control Division (WQCD).**
- **Please verify if the new lift station requires or has previously received approval of the Site Application Review Committee (SARC), the Water Quality Management Committee (WQMC) and the Pikes Peak Area Council of Governments (PPACG).**

Correct, the proposed lift station has been designed in accordance with the stated design criteria.

The lift station has previously submitted a Site Location Application Report to CDPHE. The report required review and signature from PPACG as the 208 Designated Planning Agency. The Site Location Application received approval from CDPHE on 6/24/24.

Mike McCarthy
El Paso County Public Health
719-332-5771
mikemccarthy@elpasoco.com
30August2024