



Prevent • Promote • Protect

Environmental Health Division  
1675 W. Garden of the Gods Road  
Suite 2044  
Colorado Springs, CO 80907  
(719) 578-3199 *phone*  
(719) 578-3188 *fax*  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)

**7378 Log Road, SF-25-16**

Please accept the following comments from El Paso County Public Health (EPCPH) regarding the 40-acre, 2-residential lot development project referenced above:

- Water service for the development will be provided by individual private wells, and wastewater service will be provided by onsite wastewater treatment systems (OWTS).
- There is a finding for sufficiency in terms of water quality based on the Colorado Analytical Laboratories, Inc., 25February2025, water test results. Please note there was a positive coliform test where a negative is required. This issue can usually be corrected by periodic chlorination of the well and resampling. EPCPH recommends resampling after chlorinating the well. Please call EPCPH at 717-578-3199, option 3, for directions on how to perform this chlorination procedure.
- The Entech Engineering Wastewater Study dated 10February2025 was reviewed to determine OWTS suitability for the site. Based on the report the site is found suitable for OWTS installations. OWTS's on the site will likely require a professional engineer designs due to restrictive clay soils and a high percentage of rock found in the test pits.

Mike McCarthy  
El Paso County Public Health  
[mikemccarthy@elpasoco.com](mailto:mikemccarthy@elpasoco.com)  
719-332-5771  
18July2025