



Markup Summary

dsdrice (32)




Subject: Pen
Page Label: 150
Date: 7/19/2018 5:27:25 PM
Author: dsdrice
Color: ■

Approx. Falcon DBPS floodplain



Subject: Pen
Page Label: 150
Date: 7/19/2018 5:27:25 PM
Author: dsdrice
Color: ■

Approx. Falcon DBPS floodplain




Subject: Highlight
Page Label: 150
Date: 7/20/2018 10:06:02 AM
Author: dsdrice
Color: ■

sub-basin line?




Subject: Highlight
Page Label: 150
Date: 7/20/2018 10:06:02 AM
Author: dsdrice
Color: ■

sub-basin line?




Subject: Highlight
Page Label: 150
Date: 7/20/2018 10:06:02 AM
Author: dsdrice
Color: ■

sub-basin line?




Subject: Cloud+
Page Label: 150
Date: 7/20/2018 10:32:08 AM
Author: dsdrice
Color: ■

310 cfs/
1000 cfs? Provide on each incoming reach.




Subject: Highlight
Page Label: 150
Date: 7/20/2018 10:34:01 AM
Author: dsdrice
Color: ■

Provide DPs




Subject: Highlight
Page Label: 150
Date: 7/20/2018 10:34:01 AM
Author: dsdrice
Color: ■

Provide DPs




Subject: Highlight
Page Label: 150
Date: 7/20/2018 10:34:01 AM
Author: dsdrice
Color: ■

Provide DPs




Subject: Highlight
Page Label: 150
Date: 7/20/2018 10:34:01 AM
Author: dsdrice
Color: ■

Provide DPs




Subject: Cloud+
Page Label: 150
Date: 7/20/2018 10:51:49 AM
Author: dsdrice
Color: ■

Provide dimension




Subject: Callout
Page Label: 150
Date: 7/20/2018 11:11:54 AM
Author: dsdrice
Color: ■

concrete?




Subject: Callout
Page Label: 150
Date: 7/20/2018 11:13:14 AM
Author: dsdrice
Color: ■

label grade




Subject: Cloud+
Page Label: 150
Date: 7/20/2018 11:14:01 AM
Author: dsdrice
Color: ■

Provide detail showing grading to get swale into pond.



Subject: Text Box
Page Label: 5
Date: 7/20/2018 11:39:47 AM
Author: dsdrice
Color: ■

Provide current status of CLOMR




Subject: Text Box
Page Label: 149
Date: 7/20/2018 11:42:00 AM
Author: dsdrice
Color: ■

Show and label all offsite design points and sub-basins.




Subject: Callout
Page Label: 149
Date: 7/20/2018 11:43:20 AM
Author: dsdrice
Color: ■

Label reach designations ("MT...")



Subject: Highlight
Page Label: 12
Date: 7/20/2018 11:51:10 AM
Author: dsdrice
Color: ■




Subject: Text Box
Page Label: 16
Date: 7/20/2018 12:49:06 PM
Author: dsdrice
Color: ■

Provide current status.




Subject: Cloud+
Page Label: 16
Date: 7/20/2018 12:50:14 PM
Author: dsdrice
Color: ■

Update to 2018 (final plat submittal date)



Subject: Text Box
Page Label: 104
Date: 7/20/2018 3:51:29 PM
Author: dsdrice
Color: ■

Verify compliance with flow velocity considerations for safety (<2.5 ft/sec.) Reference UDFCD V3, T-12/OS-3.



Subject: Cloud+
Page Label: 145
Date: 7/20/2018 5:55:18 PM
Author: dsdrice
Color: ■

Verify Pond SR4 inlet covers this area or re-model.




Subject: Text Box
Page Label: 117
Date: 7/20/2018 6:11:35 PM
Author: dsdrice
Color: ■

Provide all, from previous version of this report. (See previous redline pdf pgs 12-18?)




Subject: Text Box
Page Label: 144
Date: 7/20/2018 6:14:20 PM
Author: dsdrice
Color: ■

Provide peak flow table and Figure 5-3 and/or corrected Figure 6-1.




Subject: Text Box
Page Label: 150
Date: 7/20/2018 9:44:12 AM
Author: dsdrice
Color: ■

Approx. 30 Ac?




Subject: Cloud+
Page Label: 150
Date: 7/20/2018 9:51:05 AM
Author: dsdrice
Color: ■

Correct




Subject: Cloud+
Page Label: 150
Date: 7/20/2018 9:56:31 AM
Author: dsdrice
Color: ■

Falcon DBPS shows flows entering all across here. Address slope stabilization




Subject: Cloud+
Page Label: 150
Date: 7/20/2018 9:56:38 AM
Author: dsdrice
Color: ■

Adjust for legibility



Subject: Cloud+
Page Label: 150
Date: 7/20/2018 9:59:28 AM
Author: dsdrice
Color: ■

Can't read.



Subject: Text Box
Page Label: 96
Date: 7/21/2018 11:40:47 AM
Author: dsdrice
Color: ■


Adjust left axis scale



Subject: Text Box
Page Label: 150
Date: 7/21/2018 11:42:06 AM
Author: dsdrice
Color: ■

Show and label all offsite design points and sub-basins.

Provide calculations showing width and depth of flows entering pond at all applicable locations.



Subject: Callout
Page Label: 104
Date: 7/21/2018 12:15:45 PM
Author: dsdrice
Color: ■

Isn't span 8'? (current plan). This does not match plan labels of standard grate.