



September 25, 2018

Carla Anderson, RLA, ASLA
PO Box 338
Cascade, CO 80809

Dear Ms. Anderson:

Mountain View Electric Association, Inc. (MVEA) has these comments about following:

Project Name: Academy Village, Filing #3 Landscaping

MVEA has no objection to this lot specific landscaping plan as presented by Ms. Anderson with the understanding that MVEA has existing facilities within this parcel of land and request that deep root plants be placed no closer than 5 feet from any electric line and 10 feet from any above ground electric facility.

Should vegetation or structures hinder the reliability of the service or repair of service in this easement, MVEA will remove the obstacle. If at any time during or after construction, it is determined by MVEA that a relocation is necessary or to repair damaged facilities, this work will be at the expense applicant.

While MVEA has no objection to the use of the utility easement it is requested the utility easement not be vacated.

If additional information is required, please contact our office at (719) 495-2283.

Sincerely,


Cathy Hansen-Lee
Engineering Administrative Assistant

This Association is an equal opportunity provider and employer.