# ENG-SF21026-R3-CDs.pdf Markup Summary

1 (1)

Please add Project Benchmark & Basis of Bearings & 811 note.

Subject: Text Box Page Index: 1

Date: 12/27/2021 3:49:21 PM

Author: CDurham

Color: Layer: Space: Page Label: 1

Please add Project Benchmark & Basis of

Bearings & 811 note.

4 (5)

Include detail for modified inlet

Subject: Text Box Page Index: 4

Date: 12/14/2021 5:42:36 PM

Author: CDurham

Color: Layer: Space: Page Label: 4

Include detail for modified inlet

Type II Manhole. FDR references Type II MH's in

Subject: Text Box Page Index: 4

Date: 12/27/2021 3:36:53 PM

Author: CDurham

Color: Layer: Space: Page Label: 4 Type II Manhole. FDR references Type II MH's in

some locations.

EPC TYF (6" RAMP (

Subject: Text Box Page Index: 4

Date: 12/27/2021 4:27:02 PM

Author: CDurham

Color: Layer: Space: Page Label: 4

Update with new C&G detail

CURE AND GUTTER

Update with new Detectable Warning detail \_\_\_TEC

Subject: Text Box Page Index: 4

Date: 12/27/2021 4:28:19 PM

Author: CDurham

Color: Layer: Space: Page Label: 4

Update with new Detectable Warning detail

2'-0" 
Update with new Parallel Ped Ramp detail

Subject: Text Box Page Index: 4

Date: 12/27/2021 4:28:49 PM

Author: CDurham

Color: Layer: Space: Page Label: 4

Update with new Parallel Ped Ramp detail

Name to minde Monomer planning of an old when it helps as when it 1775 5000 Vo. Subject: Callout Page Index: 5

Date: 12/21/2021 1:39:35 PM

Author: CDurham

Color: Layer: Space: Page Label: 5

Need to include horizontal placement of wall and where it begins and ends.

Include location of fence in relation to wall

Subject: Callout Page Index: 5

Date: 12/21/2021 1:40:28 PM

Author: CDurham

Color: Layer:
Space:
Page Label: 5

Include location of fence in relation to wall



Subject: Callout Page Index: 5

Date: 12/27/2021 3:39:06 PM

Author: CDurham

Color: Layer: Space: Page Label: 5

4" Yellow?



Subject: Callout Page Index: 5

Date: 12/27/2021 3:39:21 PM

Author: CDurham

Color: Layer: Space: Page Label: 5

4" Yellow?



Subject: Callout Page Index: 5

Date: 12/27/2021 3:39:36 PM

Author: CDurham

Color: Layer: Space: Page Label: 5

4" Yellow?



Subject: Highlight Page Index: 5

Date: 12/27/2021 4:16:52 PM

Author: CDurham

Color: Layer: Space: Page Label: 5

Show and label mail kiosk.

Subject: Text Box Page Index: 5

Date: 12/27/2021 4:14:27 PM

Author: CDurham

Color: Layer: Space: Page Label: 5

Show and label mail kiosk.

Need to include stations for beginning and end of pavement markings. Subject: Text Box Page Index: 5

Date: 12/27/2021 4:08:05 PM

Author: CDurham

Color: Layer: Space: Page Label: 5

Need to include stations for beginning and end of

pavement markings.



Subject: Callout Page Index: 5

Date: 12/27/2021 4:21:40 PM

Author: CDurham

Color: Layer: Space: Page Label: 5

New turn arrow & solid white? Include dimensions

Include sizes for all proposed signs

Subject: Text Box Page Index: 5

Date: 12/27/2021 4:14:49 PM

Author: CDurham

Color: Layer: Space: Page Label: 5

Include sizes for all proposed signs



Subject: Text Box Page Index: 5

Date: 12/27/2021 4:18:37 PM

Author: CDurham

Color: Layer: Space: Page Label: 5

Label all existing street signs along Antelope Ridge and whether they remain or to be removed.



Subject: Callout Page Index: 5

Date: 12/28/2021 9:15:47 AM

Author: CDurham

Color: Layer: Space: Page Label: 5

Road Closed - Type III Barricade

Need to include containing with any other transports of the Chapter of the Chapte

Subject: Callout Page Index: 6

Date: 12/27/2021 4:30:11 PM

Author: CDurham

Color: Layer: Space: Page Label: 6

Need to include centerline information for all

tangents

6605 6600 Subject: Text Box Page Index: 6

Date: 12/27/2021 4:00:50 PM

Author: CDurham

Color: Layer: Space: Page Label: 6

MATCH LINE

Include roadway classification, ROW & design speed - all roadway sheets Subject: Text Box Page Index: 6

Date: 12/28/2021 8:06:02 AM

Author: CDurham

Color: Layer: Space: Page Label: 6

Include roadway classification, ROW & design

speed - all roadway sheets

Show & label sight distance at all intersections.

Subject: Text Box Page Index: 6


Date: 12/27/2021 4:32:51 PM

Author: CDurham

Color: Layer: Space: Page Label: 6

Show & label sight distance at all intersections.

7 (3)



Subject: Text Box

Page Index: 7

Date: 12/27/2021 2:09:44 PM

Author: CDurham

Color: Layer: Space:

Page Label: 7

6605 HNJ HOLL MAI HOL Subject: Text Box Page Index: 7

Date: 12/27/2021 4:22:17 PM

Author: CDurham

Color: Layer:
Space:
Page Label: 7

MATCH LINE

%

Subject: Text Box 6595 MATCH LINE Page Index: 7 Date: 12/27/2021 4:22:38 PM Author: CDurham 6590 Color: Layer: Space: Page Label: 7 8 (10) Subject: Text Box 6585 MATCH LINE Page Index: 8 Date: 12/27/2021 4:22:24 PM 6580 Author: CDurham Color: Layer: Space: Page Label: 8 Subject: Text Box MATCH LINE Page Index: 8 6560 Date: 12/27/2021 4:22:29 PM Author: CDurham Color: 6555 Layer: Space: Page Label: 8 Subject: Cloud+ Show water and sanitary crossings in profile Page Index: 8 Date: 12/28/2021 8:37:20 AM Author: CDurham Color: Layer: Space: Page Label: 8 Subject: Cloud+ Show sanitary crossings in profile Page Index: 8 Date: 12/28/2021 8:38:02 AM Author: CDurham Color: Layer: Space: Page Label: 8 Subject: Callout Missing Station Page Index: 8 Date: 12/28/2021 8:56:24 AM Author: CDurham

Color: Layer: Space: Page Label: 8



Subject: Callout Page Index: 8

Date: 12/28/2021 8:59:58 AM

Author: CDurham

Color: Layer: Space: Page Label: 8

Storm laterals should be separate profiles - All

sheets.



Subject: Callout Page Index: 8

Date: 12/28/2021 9:12:46 AM

Author: CDurham

Color: Layer:
Space:
Page Label: 8

Storm laterals should be separate profiles - All sheets.

Page Label:



Subject: Callout Page Index: 8

Date: 12/28/2021 10:02:24 AM

Author: CDurham

Color: Layer: Space: Page Label: 8

Pipe does not look like it matches pipe size called

out



Subject: Callout Page Index: 8

Date: 12/28/2021 10:03:49 AM

Author: CDurham

Color: Layer: Space: Page Label: 8

Verify size of manhole - Currently does not look like it is big enough for pipes shown.



Subject: Callout Page Index: 8

Date: 12/28/2021 10:04:00 AM

Author: CDurham

Color: Layer: Space: Page Label: 8

Verify size of manhole - Currently does not look like it is big enough for pipes shown.

9 (6)




Subject: Text Box Page Index: 9

Date: 12/27/2021 2:09:24 PM

Author: CDurham

Color: Layer: Space: Page Label: 9

%



Page Label: 10



Subject: Text Box Page Index: 10

Date: 12/27/2021 4:23:06 PM

Author: CDurham

Color: Layer: Space: Page Label: 10

MATCH LINE

11 (4)



Subject: Text Box Page Index: 11

Date: 12/27/2021 4:23:14 PM

Author: CDurham

Color: Layer: Space: Page Label: 11

MATCH LINE

| 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07 | 23-39.07

Subject: Cloud+ Page Index: 11

Date: 12/28/2021 8:38:59 AM

Author: CDurham

Color: Layer: Space: Page Label: 11

Show water and sanitary crossings in profile



Subject: Cloud+ Page Index: 11

Date: 12/28/2021 9:02:07 AM

Author: CDurham

Color: Layer: Space: Page Label: 11

Separate profile for storm.



Subject: Text Box Page Index: 11

Date: 12/28/2021 9:16:20 AM

Author: CDurham

Color: Layer: Space: Page Label: 11

Tract?

12 (2)



Subject: Text Box Page Index: 12

Date: 12/27/2021 4:23:58 PM

Author: CDurham


Color: Layer:
Space:


Page Label: 12

MATCH LINE

Show sanitary crossing in profile Page Index: 12 Date: 12/28/2021 8:39:31 AM Author: CDurham Color: Layer: Space: Page Label: 12 13 (2) Subject: Text Box MATCH LINE Page Index: 13 6630 Date: 12/27/2021 4:24:04 PM Author: CDurham 6625 Color: Layer: Space: Page Label: 13 Subject: Text Box MATCH LINE 6615 Page Index: 13 Date: 12/27/2021 4:24:09 PM Author: CDurham 6610 Color: Layer: Space: Page Label: 13 14 (7) Subject: Text Box % Page Index: 14 % Date: 12/27/2021 2:07:45 PM Author: CDurham Color: Layer: Space: Page Label: 14 Subject: Callout Per ECM 2.3.4.E Grade break difference must be Page Index: 14 less than 1% if no vertical curve provided Date: 12/27/2021 2:07:40 PM Author: CDurham Color: Layer: Space: Page Label: 14 Subject: Text Box % Page Index: 14 % Date: 12/27/2021 2:07:52 PM Author: CDurham Color: Layer: Space: Page Label: 14

Subject: Callout





Subject: Text Box Page Index: 15

Date: 12/27/2021 4:24:32 PM

Author: CDurham

Color: Layer: Space:

Page Label: 15

MATCH LINE



Subject: Callout Page Index: 15

Date: 12/28/2021 8:15:22 AM

Author: CDurham

Color: Layer: Space: Page Label: 15 Missing curve label

16 (4)



Subject: Callout Page Index: 16

Date: 12/14/2021 5:19:18 PM

Author: CDurham

Color: Layer: Space:

Page Label: 16

Per ECM 2.3.4.E Grade break difference must be less than 1% if no vertical curve provided

YEDALE WAY

Subject: Callout Page Index: 16

Date: 12/27/2021 2:05:47 PM

Author: CDurham

Color: Layer: Space:

Page Label: 16

Min K-value for sag curve = 26

6610

Subject: Text Box Page Index: 16

Date: 12/27/2021 4:24:41 PM

Author: CDurham Color:

Layer: Space: Page Label: 16 MATCH LINE

Subject: Cloud+ Page Index: 16

Date: 12/28/2021 8:41:43 AM

Author: CDurham

Color: Layer: Space:

Page Label: 16

Show water and sanitary crossings in profile

#### 17 (5)



Subject: Text Box Page Index: 17

Date: 12/27/2021 4:24:47 PM

Author: CDurham

Color: Layer: Space:

Page Label: 17

MATCH LINE



Subject: Callout Page Index: 17

Date: 12/28/2021 8:44:34 AM

Author: CDurham

Color: Layer: Space: Page Label: 17 Show water crossing in profile



Subject: Cloud+ Page Index: 17

Date: 12/28/2021 9:03:47 AM

Author: CDurham

Color: Layer: Space:

Page Label: 17

Show water and sanitary crossings in profile



Subject: Cloud+ Page Index: 17

Date: 12/28/2021 9:04:38 AM

Author: CDurham

Color: Layer: Space: Page Label: 17 Separate profile for storm laterals



Subject: Callout Page Index: 17

Date: 12/28/2021 9:04:51 AM

Author: CDurham

Color: Layer: Space: Page Label: 17 What is this?

18 (8)

ΙE

Subject: Callout Page Index: 18

Date: 12/14/2021 5:23:57 PM

Author: CDurham

Color: Layer: Space:

Page Label: 18

Min K-value for sag curve = 26

Subject: Text Box % Page Index: 18 % Date: 12/27/2021 2:11:44 PM Author: CDurham Color: Layer: Space: Page Label: 18 Subject: Text Box MATCH LINE Page Index: 18 6590 Date: 12/27/2021 4:24:55 PM Author: CDurham 6585 Color: Layer: Space: Page Label: 18 Subject: Callout Fix overlapping text Page Index: 18 Date: 12/28/2021 8:07:50 AM Author: CDurham Color: Layer: Space: Page Label: 18 Subject: Cloud+ Show water and sanitary crossings in profile Page Index: 18 Date: 12/28/2021 10:08:30 AM Author: CDurham Color: Layer: Space: Page Label: 18 Subject: Cloud+ Show sanitary crossings in profile Page Index: 18 Date: 12/28/2021 8:45:59 AM Author: CDurham Color: Layer:

Space: Page Label: 18

Subject: Callout Page Index: 18

Date: 12/28/2021 9:05:42 AM

Author: CDurham

Color: Layer: Space: Page Label: 18 Separate profile for laterals

17,0 RT = 6593.70

Subject: Callout Page Index: 18

Date: 12/28/2021 9:18:35 AM

Author: CDurham

Color: Layer:
Space:
Page Label: 18

What is this?

19 (5)

\_ % \_

Subject: Text Box Page Index: 19

Date: 12/27/2021 2:06:30 PM

Author: CDurham

Color: Layer: Space:

Page Label: 19

%

ESTING C. SHAY

Subject: Callout Page Index: 19

Date: 12/14/2021 5:25:33 PM

Author: CDurham

Color: Layer:
Space:

Page Label: 19

Per ECM 2.3.4.E Grade break difference must be

less than 1% if no vertical curve provided

6605 HOTH HOTH 6600 Subject: Text Box Page Index: 19

Date: 12/27/2021 4:25:04 PM

Author: CDurham

Color: Layer: Space:

Page Label: 19

MATCH LINE



Subject: Cloud+ Page Index: 19

Date: 12/28/2021 8:46:27 AM

Author: CDurham

Color: Layer: Space:

Page Label: 19

Show water and sanitary crossings in profile



Subject: Callout Page Index: 19

Date: 12/28/2021 9:19:07 AM

Author: CDurham

Color: Layer: Space:

Page Label: 19

Label storm crossing

20 (1)



Subject: Text Box Page Index: 20

Date: 12/27/2021 4:25:17 PM

Author: CDurham

Color: Layer: Space:

Page Label: 20

MATCH LINE

21 (5)



Subject: Text Box Page Index: 21

Date: 12/27/2021 2:13:14 PM

Author: CDurham

Color: Layer: Space:

Page Label: 21

%

06600 6600

Subject: Text Box Page Index: 21

Date: 12/27/2021 4:25:26 PM

Author: CDurham

Color: Layer: Space:

Page Label: 21

MATCH LINE

TO STATE OF THE PARTY OF T

Subject: Callout Page Index: 21

Date: 12/28/2021 8:08:50 AM

Author: CDurham Color:

Color: Layer: Space:

Page Label: 21

Call out intersection with Antelope Ridge



Subject: Callout Page Index: 21

Date: 12/28/2021 8:46:57 AM

Author: CDurham

Color: Layer: Space:

Page Label: 21

Show water crossing in profile



Subject: Cloud+ Page Index: 21

Date: 12/28/2021 8:47:18 AM

Author: CDurham

Color: Layer: Space:

Page Label: 21

Show water and sanitary crossings in profile



Subject: Text Box Page Index: 22

Date: 12/27/2021 4:25:34 PM

Author: CDurham

Color: Layer: Space:

Page Label: 22

MATCH LINE



Subject: Callout Page Index: 22

Date: 12/28/2021 8:09:14 AM

Author: CDurham

Color: Layer: Space:

Page Label: 22

Call out intersection



Subject: Callout Page Index: 22

Date: 12/28/2021 8:47:46 AM

Author: CDurham

Color: Layer: Space:

Page Label: 22

Show sanitary crossing in profile

23 (3)



Subject: Text Box Page Index: 23

**Date:** 12/28/2021 9:06:54 AM

Author: CDurham

Color: Layer: Space:

Page Label: 23

Profile needs to extend to manhole since that is match point in the next storm profile.



Subject: Callout Page Index: 23

Date: 12/28/2021 9:07:09 AM

Author: CDurham

Color: Layer: Space:

Page Label: 23

Label HGL's



Subject: Callout Page Index: 23

Date: 12/29/2021 12:26:33 PM

Author: dsdrice Color: Layer: Space:

Page Label: 23

Label as public



Subject: Cloud+ Page Index: 24

Date: 12/28/2021 9:07:59 AM

Author: CDurham

Color: Layer: Space:

Page Label: 24

Separate profile



Subject: Cloud+ Page Index: 24

Date: 12/28/2021 9:09:42 AM

Author: CDurham

Color: Layer: Space:

Page Label: 24

Inlet and manhole should be called out per stationing used in alignment & profile, not street

stations.



Subject: Callout Page Index: 24

Date: 12/28/2021 9:10:00 AM

Author: CDurham

Color: Layer: Space:

Page Label: 24

Label utilities



Subject: Callout Page Index: 24

Date: 12/28/2021 9:10:36 AM

Author: CDurham

Color: Layer: Space:

Page Label: 24

Reference GEC plan set for forebay design



Subject: Cloud+ Page Index: 24

Date: 12/28/2021 9:11:27 AM

Author: CDurham

Color: Layer: Space:

Page Label: 24

Show utility crossings in profile



Subject: Callout Page Index: 24

Date: 12/28/2021 9:20:02 AM

Author: CDurham

Color: Layer: Space:

Page Label: 24

Reference GEC plan set for forebay design

Include bearings/distances for alignments shown in plan

Subject: Text Box Page Index: 24

Date: 12/28/2021 9:20:34 AM

Author: CDurham

Color: Layer: Space: Page Label: 24

Include bearings/distances for alignments shown in plan view.

25 (12)



Subject: Callout Page Index: 25

Date: 12/28/2021 9:32:07 AM

Author: CDurham

Color: Layer: Space:

Page Label: 25

Label low point - Does it drain?

Show slopes at sidewalk landings and on sidewalk prior to landing.

Subject: Text Box Page Index: 25

Date: 12/28/2021 9:23:49 AM

Author: CDurham

Color: Layer: Space:

Page Label: 25

Show slopes at sidewalk landings and on sidewalk

prior to landing.



Subject: Callout Page Index: 25

Date: 12/28/2021 9:24:58 AM

Author: CDurham

Color: Layer: Space:

Page Label: 25

Show slopes - all details



Subject: Arrow Page Index: 25

Date: 12/28/2021 9:29:03 AM

Author: CDurham

Color: Layer: Space:

Page Label: 25



Subject: Arrow Page Index: 25

Date: 12/28/2021 9:29:13 AM

Author: CDurham

Color: Layer: Space:

Page Label: 25



Subject: Arrow Page Index: 25

Date: 12/28/2021 9:29:23 AM

Author: CDurham

Color: Layer: Space: Page Label: 25





Date: 12/28/2021 9:29:31 AM

Author: CDurham

Color: Layer: Space: Page Label: 25



Subject: Callout Page Index: 25

Date: 12/28/2021 9:31:56 AM

Author: CDurham

Color: Layer: Space: Page Label: 25



Subject: Callout Page Index: 25

**Date:** 12/28/2021 9:32:38 AM

Author: CDurham Color:

Layer: Space: Page Label: 25



Subject: Callout Page Index: 25

**Date:** 12/28/2021 9:33:10 AM

Author: CDurham

Color: Layer: Space:

Page Label: 25

Include additional spot elevations to ensure low point along curb return drains

Include spots along cross pan flowline to ensure

everything flows.

Does this drain?



Subject: Callout Page Index: 25

Date: 12/28/2021 9:38:43 AM

Author: CDurham

Color: Layer: Space:

Page Label: 25

Per ECM Section 2.3.7.F.2 Min slope for curb

return is 0.50%.



Subject: Callout Page Index: 25

Date: 12/28/2021 9:38:54 AM

Author: CDurham

Color: Layer: Space:

Page Label: 25

Per ECM Section 2.3.7.F.2 Min slope for curb

return is 0.50%.

#### 26 (5)



Subject: Callout Page Index: 26

Date: 12/28/2021 9:39:37 AM

Author: CDurham

Color: Layer: Space:

Page Label: 26

Label low point - Does it drain?



Subject: Callout Page Index: 26

Date: 12/28/2021 9:40:17 AM

Author: CDurham

Color: Layer: Space:

Page Label: 26

Label grade break



Subject: Text Box Page Index: 26

Date: 12/28/2021 9:41:29 AM

Author: CDurham

Color: Layer: Space:

Page Label: 26

Include spot elevations along flowline of cross pans to ensure there are no localized low spots in

intersections.



Subject: Callout Page Index: 26

Date: 12/28/2021 9:41:51 AM

Author: CDurham

Color: Layer: Space:

Page Label: 26

Does low point drain?



Subject: Callout Page Index: 26

Date: 12/28/2021 9:42:38 AM

Author: CDurham

Color: Layer: Space:

Page Label: 26

Does low point drain?

Subject: Callout Page Index: 27

Date: 12/28/2021 9:43:26 AM

Author: CDurham

Color: Layer: Space:

Page Label: 27

Does low point drain?



Subject: Callout Page Index: 27

Date: 12/28/2021 9:43:36 AM

Author: CDurham

Color: Layer: Space:

Page Label: 27

Does low point drain?



Subject: Text Box Page Index: 27

Date: 12/28/2021 9:43:55 AM

Author: CDurham

Color: Layer: Space:

Page Label: 27

Include spot elevations along flowline of cross pans to ensure there are no localized low spots in

intersections.

### 28 (4)



Subject: Text Box Page Index: 28

Date: 12/14/2021 5:34:11 PM

Author: CDurham

Color: Layer: Space:

Page Label: 28

If the mail kiosk is going in this tract please show on this sheet and sheet RD15.



Subject: Callout Page Index: 28

Date: 12/28/2021 9:44:41 AM

Author: CDurham

Color: Layer: Space:

Page Label: 28

MIssing existing ground on both profiles



Subject: Callout Page Index: 28

Date: 12/28/2021 9:45:27 AM

Author: CDurham

Color: Layer: Space:

Page Label: 28

Include station equation for Patterdale Place

Stationing



Subject: Callout Page Index: 28

Date: 12/28/2021 9:45:58 AM

Author: CDurham

Color: Layer:
Space:

Page Label: 28

Include station equation for Ryedale Way

Stationing

## 29 (3)



Subject: Callout Page Index: 29

**Date:** 12/14/2021 5:40:10 PM

Author: CDurham Color:

Color: Layer: Space:

Page Label: 29

Fix overlappping text & leader



Subject: Callout Page Index: 29

Date: 12/28/2021 9:46:37 AM

Author: CDurham

Color: Layer: Space:

Page Label: 29

Does low point drain?



Subject: Arrow Page Index: 29

Date: 12/29/2021 12:31:19 PM

Author: dsdrice Color: Layer: Space:

Page Label: 29