



Prevent • Promote • Protect

Environmental Health Division  
1675 W. Garden of the Gods Road  
Suite 2044  
Colorado Springs, CO 80907  
(719) 578-3199 *phone*  
(719) 578-3188 *fax*  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)

### **All About Outdoor Storage, PPR-16-037**

Please accept the following comments from El Paso County Public Health for the project referenced above:

- No water, private or public currently serves the property.
- A new onsite wastewater treatment system (OWTS) was issued on 18Aug2017 and expired 18Aug2018. El Paso County Public Health is to be contacted regarding possible renewal of the expired permit or issuance of a new permit. **Note:** The OWTS is required for all office workers and not customers. The owners are considered employees if they occupy the office. Portable toilets are for temporary use only per 8.12.E.7.a. of Chapter 8 of the El Paso County Board of Health Regulations.

The OWTS application is for a holding vault, however a water source is not proposed at this time. Holding vaults require water to function properly if installed as indicated on the site development plan.

- If earthmoving activity is in excess of 1-acre, and less than 25-acres, then a Construction Activity Permit is required. See <https://www.elpasocountyhealth.or/service/air-quality/construction-activity-application>

Mike McCarthy  
El Paso County Public Health  
Environmental Health Division  
719.575.8602  
[mikemccarthy@elpasoco.com](mailto:mikemccarthy@elpasoco.com)  
04Jan2020