



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Master Blaster Site Development Plan, PPR-17-056

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- **Water and wastewater services will be provided by Cherokee Water and Sanitation District.**
- **There is sufficient wastewater treatment capacity at the Cherokee Water and Sanitation District wastewater treatment facility to treat the projected wastewater flows from this proposed .31 acre commercial lot.**
- **Radon resistant construction building techniques/practices are encouraged to be used in this area. The EPA has determined that Colorado, and the El Paso County area have potentially higher radon levels than other areas of the country.**
- **El Paso County Public Health requires interior finish plans to be submitted for review and approval for any regulated business such a retail food establishment, automotive paint booth, sand-blasting, etc.**

**Mike McCarthy, R.E.H.S.
El Paso County Public Health
Environmental Health Division
719.575.8602
mikemccarthy@elpasoco.com
16Dec2017**