



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Chung Second Residence, VA-17-001

Please accept the following comments from El Paso County Public Health for the second residence project referenced above:

- **Water service for the existing house and the proposed second residence is by an existing individual well.**
- **Wastewater service for the existing house is provided by an onsite wastewater treatment system (OWTS) that was installed in 1999 and sized and approved for a 4 bedroom house.**
- **A New OWTS Permit is required by El Paso County Public Health for the new second residence. Full compliance with Chapter 8 of the Board of Health Regulations governing Onsite Wastewater Treatment Systems is required. Minimum OWTS installation setbacks must be maintained both internal and external to the property lines.**

**Mike McCarthy, R.E.H.S.
El Paso County Public Health
Environmental Health Division
719.575.8602
mikemccarthy@elpasoco.com
07Sept2017**